

FINAL SUBMITTAL

**VOLUME III
APPENDIX G, PART 2**

**FEASIBILITY STUDY FOR EXPANSION OF
ENERGY MONITORING AND CONTROL SYSTEM (EMCS)
FORT DRUM, NEW YORK**

Prepared for

**NORFOLK DISTRICT
CORPS OF ENGINEERS, CENAO-EN-MC
803 FRONT STREET, NORFOLK, VIRGINIA 23510**

Under

**U.S. ARMY ENGINEER DISTRICT, MOBILE
INDEFINITE DELIVERY A-E CONTRACT
CONTRACT NO. DACA01-94-D-0033
DELIVERY ORDER NO. 0006**

DISTRIBUTION STATEMENT B
Approved for public release
Distribution Unlimited

EMC No. 1406-006
January 1997

DTIC QUALITY INSPECTED 3

By

**E M C Engineers, Inc.
9755 Dogwood Road, Suite 220
Roswell, Georgia 30075
770-642-1864**

v:\1406-006\reports\final

19971022 119




DEPARTMENT OF THE ARMY
CONSTRUCTION ENGINEERING RESEARCH LABORATORIES, CORPS OF ENGINEERS
P.O. BOX 9005
CHAMPAIGN, ILLINOIS 61826-9005

REPLY TO
ATTENTION OF: TR-I Library

17 Sep 1997

Based on SOW, these Energy Studies are unclassified/unlimited.
Distribution A. Approved for public release.


Marie Wakefield,
Librarian Engineering

This report has been prepared at the request of the client, and the observations, conclusions, and recommendations contained herein constitute the opinions of E M C Engineers, Inc. In preparing this report, EMC has relied on some information supplied by the client, the client's employees, and others, which we gratefully acknowledge. Because no warranties were given with this source of information, E M C Engineers, Inc. cannot make certification or give assurances except as explicitly defined in this report.

TABLE OF CONTENTS

EXECUTIVE SUMMARY

VOLUME I

EXECUTIVE SUMMARY

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	
1.1 Authority for Energy Monitoring and Control System Feasibility Study.....	1-1
1.2 Purpose of Energy Monitoring and Control System Feasibility Study	1-1
1.3 Scope of Work	1-1
1.4 Approach	1-2
1.5 Work Accomplished	1-3
2.0 FACILITY DATA	
2.1 General	2-1
2.2 Buildings Included in Analysis	2-1
2.3 Energy Sources	2-9
2.3.1 Electricity	2-9
2.3.1.1 Electrical Demand Charges.....	2-9
2.3.1.2 Electrical Energy Charges.....	2-9
2.3.2 No. 2 Fuel Oil.....	2-9
2.3.3 High Temperature Hot Water (HTHW)	2-10
2.3.4 Natural Gas.....	2-10
2.3.5 Liquefied Petroleum Gas (LPG).....	2-10
2.4 Energy Consumption Analysis.....	2-10
2.4.1 Electricity	2-10
2.4.2 No. 2 Fuel Oil.....	2-12
2.4.3 High Temperature Hot Water (HTHW)	2-13
2.4.4 Natural Gas	2-15
2.4.5 Justification of Resource Unit Costs for Economic Analysis	2-16
2.5 Existing Controls and EMCS	2-17
2.5.1 Existing Controls.....	2-17
2.5.2 Trane Tracer 100 EMCS	2-27
3.0 ENERGY MONITORING AND CONTROL SYSTEM APPLICATION	
3.1 Energy Conserving EMCS Functions	3-1
3.2 EMCS Monitoring Functions	3-1

TABLE OF CONTENTS
(continued)

<u>Section</u>	<u>Page</u>
4.0 ENERGY MONITORING AND CONTROL SYSTEM REQUIREMENTS	
4.1 General	4-1
4.2 Configurations	4-1
4.3 Data Transmission Media.....	4-2
4.4 Sensor and Actuators.....	4-4
4.5 EMCS Operations and Maintenance.....	4-4
4.5.1 EMCS Operations	4-4
4.5.2 EMCS Maintenance	4-4
4.6 Authority	4-5
4.7 Repair of Existing Controls.....	4-5
5.0 ANALYSIS METHODOLOGY	
5.1 Procedures	5-1
5.2 I/O Summary Tables.....	5-2
5.3 Energy Savings	5-2
5.4 Construction Costs.....	5-3
5.5 EMCS Prioritization	5-3
5.6 EMCS Alternatives Evaluation.....	5-3
6.0 RESULTS OF ANALYSIS	
6.1 General	6-1
6.2 Building Summary.....	6-1
6.3 Resulting Configuration	6-1
6.4 Energy Savings	6-4
6.5 Implementation Costs.....	6-5
6.6 Economic Summary	6-6
6.7 Life Cycle Cost Analysis.....	6-7
6.8 DD1391	6-7
7. CONCLUSIONS AND RECOMMENDATIONS	

LIST OF TABLES

<u>Table</u>	<u>Page</u>
ES-1 System Economics.....	ES-4
ES-2 Similar Buildings.....	ES-5
ES-3 Energy Savings Summary	ES-7
ES-4 Energy Cost Savings Summary	ES-7
2-1 Buildings Evaluated for EMCS.....	2-2
2-2 Buildings of Similar Construction	2-7
2-3 Electrical Consumption - FY94	2-11
2-4 No. 2 Fuel Oil Consumption - FY94.....	2-12
2-5 HTHW Consumption - FY94.....	2-14
2-6 Natural Gas Consumption - FY93.....	2-15
6-1 Building Economic Summary	6-2
6-2 Energy Savings Summary	6-4
6-3 Implementation Costs.....	6-5
6-4 System Economics	6-6

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
2-1 Electrical Consumption - FY94	2-11
2-2 No. 2 Fuel Oil Consumption - FY94.....	2-13
2-3 HTHW Consumption - FY94.....	2-14
2-4 Natural Gas Consumption - FY93.....	2-16
2-5 Trane Tracer 100 EMCS	2-18

APPENDICES

- A SCOPE OF WORK AND CONTRACT DOCUMENTS
- B EMCS APPLICATIONS PROGRAMS
- C TYPICAL HVAC SYSTEM
 - C.1 TYPICAL HVAC SYSTEM SCHEMATICS
 - C.2 TYPICAL HVAC SYSTEM I/O SUMMARY TABLES
 - C.3 TYPICAL HVAC SYSTEM COST ESTIMATES
 - C.4 TYPICAL HVAC SYSTEM MANUFACTURERS' CUTSHEETS
- D ALGORITHMS AND ENERGY CONSTANTS USED IN ANALYSIS
- E HVAC SYSTEM ECONOMIC SUMMARY
- F COST ESTIMATES

Volume II

- G ENERGY CALCULATIONS, PART 1
 - G.1 ENERGY CONSTANT CALCULATIONS
 - G.2 ENERGY SAVINGS CALCULATIONS

Volume III

- G ENERGY CALCULATIONS, PART 2

Volume IV

- H FIELD SURVEY NOTES
- I COMPUTER SIMULATIONS

LIST OF ABBREVIATIONS

AC	-	air conditioning
ACC	-	anticipated contract cost
ACCU	-	air cooled condensing unit
ACM	-	asbestos containing material
ACU(s)	-	auxiliary control unit(s)
AHU	-	air handling unit
AI	-	analog input
AO	-	analog output
ASCII	-	American Standard Code for Information Interchange
ASHRAE	-	American Society of Heating, Refrigeration, and Air conditioning Engineers
B/C	-	benefit-to-cost ratio
BCD	-	binary coded decimal
BLDG	-	building
BEACON	-	Building Energy Simulation Program
Btu	-	British thermal units
Btuh	-	British thermal units per hour
B/W	-	black and white
C	-	Celsius
CCC	-	central communications controller
ccf	-	one hundred (100) cubic feet
CCU	-	central control unit

cf	-	cubic foot, cubic feet
cfm	-	cubic feet per minute
CLM	-	command line mnemonic
CLMI	-	command line mnemonic interpreter
COE	-	Corps of Engineers
COS	-	central operator station
CPU	-	central processing unit
CRT	-	cathode ray tube
CU(s)	-	control unit(s)
CWE	-	current working estimate
d	-	day(s)
DCP	-	duty cycle program
DEH	-	Directorate of Engineering and Housing
DHW	-	direct memory access
DI	-	digital input
DO	-	digital output
DOD	-	Department of Defense
DPW	-	Department of Public Works
DTM	-	data transmission media
DX	-	direct expansion
E/C	-	energy-to-cost ratio
ECIP	-	Energy Conservation Investment Program
ECO	-	energy conservation opportunity

EEAP	-	energy engineering analysis program
eff	-	efficiency
elec.	-	electricity
EMC	-	EMC Engineers, Inc.
EMCS	-	energy monitoring and control system
EMI	-	electromagnetic interference
ESCO	-	energy service company
EZ-DOE	-	Building Energy Simulation Program
F	-	Fahrenheit
FO	-	fiber optic(s)
ft	-	foot, feet
ft ²	-	square feet
FY	-	fiscal year
gal	-	gallon(s)
hp	-	horsepower
hr	-	hours(s)
H & V	-	heating and ventilating
HVAC	-	heating, ventilation, and air conditioning
in.	-	inch(es)
I/O	-	input/output
kBtu	-	one thousand British thermal units
kcf	-	one thousand cubic feet

klb	-	one thousand pounds
kva	-	kilovolt - ampere
kW	-	kilowatt, one thousand watts
kWh	-	kilowatt-hour, one thousand watt-hours
lb	-	pound(s)
LCCA	-	life cycle cost analysis
LCCID	-	life cycle cost in design
LED	-	light emitting diode
LPG	-	liquefied petroleum gas
MAU	-	make-up air unit
MBtu	-	one million Btu
MCR	-	master control room
MHz	-	megahertz
Mh	-	man-hours(s)
mo	-	months(s)
MW	-	megawatt, one million watts
MWh	-	megawatt-hour, one million watt-hours
MZAHU	-	Multizone air handling unit
NA	-	Not active or Not applicable
NG	-	natural gas
NOAA	-	National Oceanic and Atmospheric Administration
no.	-	number
OA	-	outside air

O&M	-	operation and maintenance
PC	-	personal computer
PM	-	preventative maintenance
PROM	-	programmable read-only memory
psi(a)(g)	-	pounds per square inch (absolute) (gage)
RAM	-	random access memory
RCU(s)	-	remote control unit(s)
RTC	-	real-time clock
RTDOS/E	-	real-time disk operating system /executive
S&A	-	Supervision and Administration
scfm	-	sea-level cubic feet per minute
SES	-	shared energy savings
SIOH	-	supervision, inspection, and overhead
SIR	-	savings-to-investment ratio
SPW	-	single present worth
sq.ft.	-	square feet
st/sp	-	start/stop
stm	-	steam
SZAHU	-	single zone air handling unit
t	-	ton
temp	-	temperature
TRY	-	test reference year

UA	-	overall heat transfer coefficient (Btu/hr/ft ² /°F)
UCU(s)	-	unitary control unit(s)
UH	-	unit heater
UMCS	-	utility monitoring and control system
UPW	-	uniform present worth
VAV	-	variable air volume
wk	-	week(s)
yr	-	year(s)

ENERGY CALCULATIONS

BUILDING 10200

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10200

Building Sq.Ft.: 11,248

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

09-Apr-95

PAGE 2 OF 2

Bldg Number: 10200

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	147.5	
Sub Total	0.0	8,501.7	147.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	159.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10200

Building Sq.Ft.: 11,248

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 09-Apr-95
PAGE 2 OF 2

Bldg Number: 10200
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	28.1	
Sub Total	0.0	4,791.4	28.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	30.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10200

Building Sq.Ft.: 11,248

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 10200

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10200

Building Sq.Ft.: 11,248

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 10200
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	526.9	
Sub Total	0.0	2,397.8	526.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	40.9	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	568.6	3

ENERGY CALCULATIONS

BUILDING 10205

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10205

Building Sq.Ft.: 18,546

System Type 11

System Name: CONDENSING UNIT

System Number: ACC1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
11	BRICK	DENTAL CLINIC	700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	50
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	0.8
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	4.34E-03	4.34E-03
COAUHC	1.67E-03	1.67E-03
HOAOH	232.16	232.16
HOAOHC	142.48	142.48
COAOC	8.51E-03	8.51E-03
COAOHC	3.26E-03	3.26E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	8.14E-04	8.14E-04
NSUHC	5.00E-04	5.00E-04
DDCCHC	9.67E-05	9.67E-05
DDCCC	2.52E-04	2.52E-04
DSC	4.35E+03	4.35E+03
NSC	5.41E+04	5.41E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10205

System Type 11

System Name: CONDENSING UNIT

System Number: ACC1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,439.6	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	4.5	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	4.5	4,865.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	478.5	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	4.5	5,344.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10205

Building Sq.Ft.: 18,546

System Type 7

System Name: VAV AHU

System Number: AHU1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
11	BRICK	DENTAL CLINIC	700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	20.75
Load Factor	0.8
CFM - HTG	10430
CFM - CLG	17500
% OA	30.00%
% Area	13.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	0.8
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	4.34E-03	4.34E-03
COAUHC	1.67E-03	1.67E-03
HOAOH	232.16	232.16
HOAOHC	142.48	142.48
COAOC	8.51E-03	8.51E-03
COAOHC	3.26E-03	3.26E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	8.14E-04	8.14E-04
NSUCHC	5.00E-04	5.00E-04
DDCCHC	9.67E-05	9.67E-05
DDCCC	2.52E-04	2.52E-04
DSC	4.35E+03	4.35E+03
NSC	5.41E+04	5.41E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10205
System Type 7
System Name: VAV AHU
System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	116,476.7	0.0	
Optimum ST/SP	0.0	2,641.2	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	28.1	0.0	0.0	
Night Setback	0.0	0.0	130.4	
Sub Total	28.1	119,117.8	130.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	1,644.1	0.0	
DDC Control	0.0	16,102.0	10.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	28.1	136,863.9	140.9	6

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10205

Building Sq.Ft.: 18,546

System Type 12

System Name: BASEBOARD RADIATION

System Number: HX1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
11	BRICK	DENTAL CLINIC	700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	87.00%
TON CAPC.	0
MBTU CAPC.	0.94283
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAV	1,960	
Heating HRSAV	3,136	
C/H HRSAV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	4.34E-03	4.34E-03
COAUHC	1.67E-03	1.67E-03
HOAOH	232.16	232.16
HOAOHC	142.48	142.48
COAOC	8.51E-03	8.51E-03
COAOHC	3.26E-03	3.26E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	8.14E-04	8.14E-04
NSUCHC	5.00E-04	5.00E-04
DDCCHC	9.67E-05	9.67E-05
DDCCC	2.52E-04	2.52E-04
DSC	4.35E+03	4.35E+03
NSC	5.41E+04	5.41E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10205
System Type 12
System Name: BASEBOARD RADIATION
System Number: HX1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,703.1	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	872.4	
Sub Total	0.0	2,865.2	872.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	70.2	
HW OA Reset	0.0	0.0	7.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,865.2	949.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10205

Building Sq.Ft.: 18,546

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
11	BRICK	DENTAL CLINIC	700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.333333
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3064
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	4.34E-03	4.34E-03
COAUHC	1.67E-03	1.67E-03
HOAOH	232.16	232.16
HOAOHC	142.48	142.48
COAOC	8.51E-03	8.51E-03
COAOHC	3.26E-03	3.26E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	8.14E-04	8.14E-04
NSUHC	5.00E-04	5.00E-04
DDCCHC	9.67E-05	9.67E-05
DDCCC	2.52E-04	2.52E-04
DSC	4.35E+03	4.35E+03
NSC	5.41E+04	5.41E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10205

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	959.3	0.0	
Optimum ST/SP	0.0	57.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	1,016.8	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,016.8	2.3	3

ENERGY CALCULATIONS

BUILDING 10207

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 4
System Name: SINGLE ZONE AHU
System Number: AHU1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	3.1
Load Factor	0.8
CFM - HTG	2500
CFM - CLG	2500
% OA	35.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	2,100
Heating HRSON	2,112	3,360
C/H HRSON	3,441	5,475
Cooling HRSAB	780	
Heating HRSAB	1,248	
C/H HRSAB	2,034	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10207

System Type 4

System Name: SINGLE ZONE AHU

System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,403.0	0.0	
Optimum ST/SP	0.0	440.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	4.7	0.0	0.0	
Night Setback	0.0	0.0	87.5	
Sub Total	4.7	11,843.0	87.5	
Economizer	0.0	982.7	0.0	
Ventilation/Recirculation	0.0	614.2	10.7	
DDC Control	0.0	0.0	32.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	4.7	13,439.9	130.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	1500	1500	1500	1500	1500	1500	1500

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	4500
CFM - CLG	4500
% OA	35.00%
% Area	26.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	1,260
Heating HRSON	2,112	2,016
C/H HRSON	3,441	3,285
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10207
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU2

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	151.7	
Sub Total	10.8	1,012.1	151.7	
Economizer	0.0	1,768.9	0.0	
Ventilation/Recirculation	0.0	1,105.5	0.0	
DDC Control	0.0	0.0	56.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	3,886.4	207.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	6100
CFM - CLG	6100
% OA	35.00%
% Area	36.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	2,100
Heating HRSON	2,112	3,360
C/H HRSON	3,441	5,475
Cooling HRSAV	780	
Heating HRSAV	1,248	
C/H HRSAV	2,034	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10207

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU3

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	27,156.9	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	210.0	
Sub Total	10.8	28,169.0	210.0	
Economizer	0.0	2,397.8	0.0	
Ventilation/Recirculation	0.0	1,498.5	0.0	
DDC Control	0.0	0.0	77.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	32,065.4	287.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU4

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	4000
CFM - CLG	4000
% OA	35.00%
% Area	23.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	2,100
Heating HRSON	2,112	3,360
C/H HRSON	3,441	5,475
Cooling HRSVA	780	
Heating HRSVA	1,248	
C/H HRSVA	2,034	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10207
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU4

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	21,576.6	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	134.2	
Sub Total	10.8	22,588.7	134.2	
Economizer	0.0	1,572.3	0.0	
Ventilation/Recirculation	0.0	982.6	17.1	
DDC Control	0.0	0.0	49.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	25,143.7	200.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10207

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10207

Building Sq.Ft.:

18,199

System Type: 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10207
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10207

Building Sq.Ft.: 18,199

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAV	1,820	
Heating HRSAV	2,912	
C/H HRSAV	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10207
System Type: 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10207

Building Sq.Ft.: 18,199

System Type 8

System Name: CHILLER AND PUMPS

System Number: WC1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	73
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	0.8
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10207
System Type 8
System Name: CHILLER AND PUMPS
System Number: WC1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	9,797.8	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	10.8	10,809.9	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	698.6	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	11,508.5	0.0	3

ENERGY CALCULATIONS

BUILDING 10210

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10210

Building Sq.Ft.: 12,448

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 09-Apr-95

PAGE 2 OF 2

Bldg Number: 10210

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	175.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10210

Building Sq.Ft.: 12,448

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 09-Apr-95

PAGE 2 OF 2

Bldg Number: 10210

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10210

Building Sq.Ft.: 12,448

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10210

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10210

Building Sq.Ft.: 12,448

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10210

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.2	
Sub Total	0.0	2,397.8	583.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.2	3

ENERGY CALCULATIONS

BUILDING 10212

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,212

Building Sq.Ft.: 51,794

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,212
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,212

Building Sq.Ft.: 51,794

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,212
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10212
System Type 14
System Name: VENTILATION
System Number: AHU1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCCHC	0.00E+00	0.00E+00
DDCCCI	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10212
System Type 14
System Name: VENTILATION
System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU-3

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4566
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10212
System Type: 14
System Name: VENTILATION
System Number: AHU-3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU4

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCW/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10212

System Type 14

System Name: VENTILATION

System Number: AHU4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
KW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10212
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10212
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10212

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10212
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 34,184

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10212

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10212

Building Sq.Ft.: 34,184

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10212

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.9	3

ENERGY CALCULATIONS

BUILDING 10214

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 48,916

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10214
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,214

Building Sq.Ft.: 48,916

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,214

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 12,240

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10214
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 12,240

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10214

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 12,240

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10214

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 36,712

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10214

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	87.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	87.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10214

Building Sq.Ft.: 36,712

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10214

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	87.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	87.5	3

ENERGY CALCULATIONS

BUILDING 10220

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10220

Building Sq.Ft.: 12,448

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10220
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	175.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10220

Building Sq.Ft.: 12,448

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCW/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10220

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10220

Building Sq.Ft.: 12,448

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10220
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10220

Building Sq.Ft.: 12,448

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10220
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.2	
Sub Total	0.0	2,397.8	583.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.2	3

ENERGY CALCULATIONS

BUILDING 10222

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 51,794

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,900	3,360
Heating HRSON	3,040	5,376
C/H HRSON	4,954	8,760
Cooling HRSAV	1,460	
Heating HRSAV	2,336	
C/H HRSAV	3,806	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

*ESTIMATED PUMP ON 50% OF UNOCCUPIED HOURS

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,572.8	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	3,860.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,860.3	2.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,222

Building Sq.Ft.: 51,794

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,222

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10222
System Type: 14
System Name: VENTILATION
System Number: AHU1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU-2

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10222
System Type 14
System Name: VENTILATION
System Number: AHU-2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type: 14
System Name: VENTILATION

System Number: AHU3

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type 14

System Name: VENTILATION

System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU4

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type 14

System Name: VENTILATION

System Number: AHU4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10222

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10222
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 34,184

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	26.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRE HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10222

Building Sq.Ft.: 34,184

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRE HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10222

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.9	3

ENERGY CALCULATIONS

BUILDING 10224

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 48,961

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

EMC NO.: 1406-006

DATE: 14-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	14.77
HOAOHC	110.07	9.07
COAOC	0.00E+00	2.10E-05
COAOHC	0.00E+00	8.04E-06
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	1.26E-05
NSUCHC	0.00E+00	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	8.71E+03
NSC	4.86E+04	5.97E+04
FV	0	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 14-Apr-95

PAGE 2 OF 2

Bldg Number: 10224

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,224

Building Sq.Ft.: 48,916

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,224
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 12,240

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10224

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 12,240

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10224
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 12,240

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10224
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	101.2	
Sub Total	0.0	1,683.3	101.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	113.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 36,712

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10224

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	87.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	87.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10224

Building Sq.Ft.: 36,712

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10224

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	87.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	87.5	3

ENERGY CALCULATIONS

BUILDING 10230

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10230

Building Sq.Ft.: 12,448

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

09-Apr-95

PAGE 2 OF 2

Bldg Number: 10230

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	175.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10230

Building Sq.Ft.: 12,448

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 09-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

09-Apr-95

PAGE 2 OF 2

Bldg Number: 10230

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10230

Building Sq.Ft.: 12,448

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10230
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10230

Building Sq.Ft.: 12,448

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10230

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.2	
Sub Total	0.0	2,397.8	583.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.2	3

ENERGY CALCULATIONS

BUILDING 10232

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,232

Building Sq.Ft.: 51,794

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,232

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,232

Building Sq.Ft.: 51,794

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,232

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10232
System Type 14
System Name: VENTILATION
System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type
System Name: VENTILATION

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 14

System Name: VENTILATION

System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU3

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10232
System Type: 14
System Name: VENTILATION
System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 14
System Name: VENTILATION
System Number: AHU-4

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4779
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 14

System Name: VENTILATION

System Number: AHU-4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10232
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10232
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 34,184

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	80.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	80.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10232

Building Sq.Ft.: 34,184

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10132

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	77.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	77.5	3

ENERGY CALCULATIONS

BUILDING 10234

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,234

Building Sq.Ft.: 57,581

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,234

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,234

Building Sq.Ft.: 57,581

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,234

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type: 14
System Name: VENTILATION
System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10234
System Type 14
System Name: VENTILATION
System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type: 14
System Name: VENTILATION
System Number: AHU-2

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10234
System Type 14
System Name: VENTILATION
System Number: AHU-2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type: 14
System Name: VENTILATION
System Number: AHU3

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10234
System Type 14
System Name: VENTILATION
System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type 14

System Name: VENTILATION

System Number: AHU-4

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4779
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 12-Apr-95
PAGE 2 OF 2

Bldg Number: 10234
System Type 14
System Name: VENTILATION
System Number: AHU-4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10234

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	121.4	
Sub Total	0.0	1,683.3	121.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	136.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10234

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	121.4	
Sub Total	0.0	1,683.3	121.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	136.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10234

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	121.4	
Sub Total	0.0	1,683.3	121.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	136.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 19,578

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10234

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	121.4	
Sub Total	0.0	1,683.3	121.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	136.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 38,003

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/MLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10234

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	88.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	88.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10234

Building Sq.Ft.: 38,003

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10234

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	88.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	88.9	3

ENERGY CALCULATIONS

BUILDING 10250

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10250

Building Sq.Ft.: 18,553

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	8000
CFM - CLG	0
% OA	100.00%
% Area	17.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAH	0.00	0.00
HOAH	0.00	0.00
COAH	0.00E+00	0.00E+00
COAH	0.00E+00	0.00E+00
HOAH	39.67	39.67
HOAH	24.34	24.34
COAH	0.00E+00	0.00E+00
COAH	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUC	0.00E+00	0.00E+00
NSUC	0.00E+00	0.00E+00
DDCHC	0.00E+00	0.00E+00
DDCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,789.6	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	174.4	
Sub Total	0.0	12,801.7	174.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	63.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,801.7	237.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10250

Building Sq.Ft.: 18,553

System Type 2

System Name: H&V UNIT

System Number: AHU2

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	8
Load Factor	0.8
CFM - HTG	5265
CFM - CLG	0
% OA	25.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250
System Type 2
System Name: H&V UNIT
System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	14,042.8	0.0	
Optimum ST/SP	0.0	1,079.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	296.2	
Sub Total	0.0	15,122.3	296.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	107.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	15,122.3	403.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10250

Building Sq.Ft.: 18,553

System Type 2

System Name: H&V UNIT

System Number: AHU3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/MLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	4670
CFM - CLG	0
% OA	100.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250

System Type: 2

System Name: H&V UNIT

System Number: AHU3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,001.1	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	261.3	
Sub Total	0.0	18,308.0	261.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	94.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	18,308.0	355.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10250

Building Sq.Ft.: 18,553

System Type 2

System Name: H&V UNIT

System Number: AHU4

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	7430
CFM - CLG	0
% OA	5.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250

System Type 2

System Name: H&V UNIT

System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,236.9	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	418.1	
Sub Total	0.0	27,177.0	418.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	151.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	27,177.0	569.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10250

Building Sq.Ft.: 18,553

System Type 2

System Name: H&V UNIT

System Number: AHU5

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6
Load Factor	0.8
CFM - HTG	3145
CFM - CLG	0
% OA	5.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAV	938	
Heating HRSAV	1,501	
C/H HRSAV	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250
System Type 2
System Name: H&V UNIT
System Number: AHU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	10,725.7	0.0	
Optimum ST/SP	0.0	824.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	174.2	
Sub Total	0.0	11,550.2	174.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	62.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	11,550.2	237.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10250

Building Sq.Ft.: 18,553

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	600
CFM - CLG	0
% OA	0.00%
% Area	1.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,614.1	0.0	
Optimum ST/SP	0.0	567.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	27.9	
Sub Total	0.0	7,181.9	27.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	7,181.9	37.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10250

Building Sq.Ft.: 18,553

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	7.40%
TON CAPC.	0
MBTU CAPC.	1.5064
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAV	840	
Heating HRSAV	1,344	
C/H HRSAV	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10250

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,349.5	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	128.9	
Sub Total	0.0	3,637.0	128.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	46.6	
HW OA Reset	0.0	0.0	11.1	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,637.0	186.7	3

ENERGY CALCULATIONS

BUILDING 10270

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10270

System Type 2

System Name: H&V UNIT

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.1	
Sub Total	0.0	83,884.9	24.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	30.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10270
System Type 2
System Name: H&V UNIT
System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.1	
Sub Total	0.0	101,035.1	24.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	30.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10270
System Type 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.1	
Sub Total	0.0	83,884.9	24.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	30.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10270

Building Sq.Ft.: 25,984

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10270
System Type 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.0	
Sub Total	0.0	83,884.9	12.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	15.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.4	
Sub Total	0.0	56,826.3	14.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.2	
Sub Total	0.0	56,826.3	7.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10270

Building Sq.Ft.: 25,984

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.4	
Sub Total	0.0	56,826.3	14.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.4	
Sub Total	0.0	56,826.3	14.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10270

Building Sq.Ft.: 25,984

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.2	
Sub Total	0.0	56,826.3	7.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10270

Building Sq.Ft.: 25,984

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRS AV	2,040	
Heating HRS AV	3,264	
C/H HRS AV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10270

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.0	
Sub Total	0.0	56,826.3	12.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	15.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10270

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	4.8	
Sub Total	0.0	29,644.0	4.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	6.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	57.7	
Sub Total	0.0	12,616.7	57.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.7	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	99.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10270

Building Sq.Ft.:

25,984

System Type

9

System Name:

CONVERTER AND PUMPS

System Number:

HTP2

EMC NO.: 1406-006

DATE:

05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10270

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10270

Building Sq.Ft.: 25,984

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10270
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10412

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,412

Building Sq.Ft.: 54,872

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,412

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,412

Building Sq.Ft.: 59,078

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,412
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type: 14

System Name: VENTILATION

System Number: AHU1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10412

System Type 14

System Name: VENTILATION

System Number: AHU1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type: VENTILATION

System Name: AHU2

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10412
System Type 14
System Name: VENTILATION
System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type 14

System Name: VENTILATION

System Number: AHU-3

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4566
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10412
System Type 14
System Name: VENTILATION
System Number: AHU-3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type: 14

System Name: VENTILATION

System Number: AHU-4

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4779
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10412
System Type 14
System Name: VENTILATION
System Number: AHU-4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10412
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	115.7	
Sub Total	0.0	1,683.3	115.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	129.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10412

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	115.7	
Sub Total	0.0	1,683.3	115.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	129.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10412

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	115.7	
Sub Total	0.0	1,683.3	115.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	129.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 18,656

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10412
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	115.7	
Sub Total	0.0	1,683.3	115.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	129.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 38,216

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10412

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	84.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	84.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10412

Building Sq.Ft.: 38,216

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10412

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	84.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	84.8	3

ENERGY CALCULATIONS

BUILDING 10400

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10400

Building Sq.Ft.:

11,249

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10400

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	147.6	
Sub Total	0.0	8,501.7	147.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	159.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10400

Building Sq.Ft.: 11,249

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10400

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	28.1	
Sub Total	0.0	4,791.4	28.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	30.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10400

Building Sq.Ft.: 11,249

System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10400

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10400

Building Sq.Ft.: 11,249

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10400
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	527.0	
Sub Total	0.0	2,397.8	527.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	40.9	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	568.7	3

ENERGY CALCULATIONS

BUILDING 10410

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10410

Building Sq.Ft.: 12,450

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10410

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10410

Building Sq.Ft.: 12,450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10410

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10410

Building Sq.Ft.: 12,450

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10410

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10410

Building Sq.Ft.: 12,450

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10410

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.3	3

ENERGY CALCULATIONS

BUILDING 10414

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,414

Building Sq.Ft.: 59,078

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,414

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,414

Building Sq.Ft.: 59,078

System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,414
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type: 14
System Name: VENTILATION
System Number: AHU1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 14

System Name: VENTILATION

System Number: AHU1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 14

System Name: VENTILATION

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 14

System Name: VENTILATION

System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 14

System Name: VENTILATION

System Number: AHU3

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 14

System Name: VENTILATION

System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 14

System Name: VENTILATION

System Number: AHU4

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 14

System Name: VENTILATION

System Number: AHU4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10414
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	124.6	
Sub Total	0.0	1,683.3	124.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	139.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10414
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	124.6	
Sub Total	0.0	1,683.3	124.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	139.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	124.6	
Sub Total	0.0	1,683.3	124.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	139.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 20,087

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	124.6	
Sub Total	0.0	1,683.3	124.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	139.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 38,991

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10414
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	91.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	91.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10414

Building Sq.Ft.: 38,991

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10414

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	91.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	91.3	3

ENERGY CALCULATIONS

BUILDING 10420

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10420

Building Sq.Ft.: 12,450

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10420

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10420

Building Sq.Ft.: 12,450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10420

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10420

Building Sq.Ft.: 12,450

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10420
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10420

Building Sq.Ft.: 12,450

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10420

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.3	3

ENERGY CALCULATIONS

BUILDING 10422

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,422

Building Sq.Ft.: 47,300

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,422

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,422

Building Sq.Ft.: 47,300

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,422
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10422

Building Sq.Ft.: 11,825

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10422
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	97.8	
Sub Total	0.0	1,683.3	97.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	109.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10422

Building Sq.Ft.: 11,825

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10422

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	97.8	
Sub Total	0.0	1,683.3	97.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	109.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10422

Building Sq.Ft.: 11,825

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10422

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	97.8	
Sub Total	0.0	1,683.3	97.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	109.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10422

Building Sq.Ft.: 35,475

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10422

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	84.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	84.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10422

Building Sq.Ft.: 35,475

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10422

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	84.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	84.5	3

ENERGY CALCULATIONS

BUILDING 10450

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10450

Building Sq.Ft.: 9,486

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	8000
CFM - CLG	0
% OA	100.00%
% Area	17.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	13,165.1	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	174.4	
Sub Total	0.0	14,177.2	174.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	63.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	14,177.2	237.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type: 2

System Name: H&V UNIT

System Number: AHU2

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	8
Load Factor	0.8
CFM - HTG	5265
CFM - CLG	0
% OA	25.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAV	938	
Heating HRSAV	1,501	
C/H HRSAV	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type 2

System Name: H&V UNIT

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	14,042.8	0.0	
Optimum ST/SP	0.0	1,079.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	151.4	
Sub Total	0.0	15,122.3	151.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	54.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	15,122.3	206.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type 2

System Name: H&V UNIT

System Number: AHU3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	4670
CFM - CLG	0
% OA	100.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type 2

System Name: H&V UNIT

System Number: AHU3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,001.1	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	133.6	
Sub Total	0.0	18,308.0	133.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	48.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	18,308.0	181.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type 2

System Name: H&V UNIT

System Number: AHU4

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	7430
CFM - CLG	0
% OA	5.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10450
System Type 2
System Name: H&V UNIT
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,236.9	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	213.8	
Sub Total	0.0	27,177.0	213.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	77.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	27,177.0	291.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type 2

System Name: H&V UNIT

System Number: AHU5

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6
Load Factor	0.8
CFM - HTG	3145
CFM - CLG	0
% OA	5.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAV	938	
Heating HRSAV	1,501	
C/H HRSAV	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOH	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type 2

System Name: H&V UNIT

System Number: AHU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	10,725.7	0.0	
Optimum ST/SP	0.0	824.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	89.1	
Sub Total	0.0	11,550.2	89.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	32.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	11,550.2	121.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	600
CFM - CLG	0
% OA	0.00%
% Area	1.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,614.1	0.0	
Optimum ST/SP	0.0	567.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.3	
Sub Total	0.0	7,181.9	14.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	7,181.9	19.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10450

Building Sq.Ft.: 9,486

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	7.40%
TON CAPC.	0
MBTU CAPC.	1.5064
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOHC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10450

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,349.5	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	65.9	
Sub Total	0.0	3,637.0	65.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	23.8	
HW OA Reset	0.0	0.0	11.1	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,637.0	100.9	3

ENERGY CALCULATIONS

BUILDING 10470

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 2

System Name: H&V UNIT

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	29.8	
Sub Total	0.0	83,884.9	29.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	7.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	37.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOHC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10470
System Type 2
System Name: H&V UNIT
System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	29.8	
Sub Total	0.0	101,035.1	29.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	7.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	37.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470
System Type: 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	29.8	
Sub Total	0.0	83,884.9	29.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	7.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	37.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 11-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 11-Apr-95

PAGE 2 OF 2

Bldg Number: 10470
System Type 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.9	
Sub Total	0.0	83,884.9	14.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	18.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	17.9	
Sub Total	0.0	56,826.3	17.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	22.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	8.9	
Sub Total	0.0	56,826.3	8.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	11.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSVA	2,040	
Heating HRSVA	3,264	
C/H HRSVA	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	17.9	
Sub Total	0.0	56,826.3	17.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	22.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	17.9	
Sub Total	0.0	56,826.3	17.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	22.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	8.9	
Sub Total	0.0	56,826.3	8.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	11.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10470
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.9	
Sub Total	0.0	56,826.3	14.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	6.0	
Sub Total	0.0	29,644.0	6.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	7.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10470

Building Sq.Ft.: 32,213

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10470
System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	71.6	
Sub Total	0.0	12,616.7	71.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	18.3	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	116.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/MLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10470

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10470

Building Sq.Ft.: 32,213

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRS AV	2,040	
Heating HRS AV	3,264	
C/H HRS AV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DCCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10470
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10480

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
KW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10480
System Type 2
System Name: H&V UNIT
System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	26.0	
Sub Total	0.0	83,884.9	26.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	32.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10480
System Type: 2
System Name: H&V UNIT
System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	26.0	
Sub Total	0.0	101,035.1	26.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	32.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10480
System Type 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	26.0	
Sub Total	0.0	83,884.9	26.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	32.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	13.0	
Sub Total	0.0	83,884.9	13.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	16.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.6	
Sub Total	0.0	56,826.3	15.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10480

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.8	
Sub Total	0.0	56,826.3	7.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10480

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.6	
Sub Total	0.0	56,826.3	15.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.6	
Sub Total	0.0	56,826.3	15.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.8	
Sub Total	0.0	56,826.3	7.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10480

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	13.0	
Sub Total	0.0	56,826.3	13.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	16.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	5.2	
Sub Total	0.0	29,644.0	5.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	6.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10480

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	62.3	
Sub Total	0.0	12,616.7	62.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.9	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	104.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10480

Building Sq.Ft.: 28,057

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
KW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10480
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10480

Building Sq.Ft.: 28,057

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10480
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10500

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10500

Building Sq.Ft.: 11,249

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10500

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	147.6	
Sub Total	0.0	8,501.7	147.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	159.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10500

Building Sq.Ft.: 11,249

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10500

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	28.1	
Sub Total	0.0	4,791.4	28.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	30.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10500

Building Sq.Ft.: 12,450

System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10500
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10500

Building Sq.Ft.: 11,249

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10500

System Type: 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	527.0	
Sub Total	0.0	2,397.8	527.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	40.9	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	568.7	3

ENERGY CALCULATIONS

BUILDING 10502

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10502
System Type: 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10502
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.8216
kW/Ton	0
MOSON	7
EFF	0.8
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAV	1,820	
Heating HRSAV	2,912	
C/H HRSAV	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10502
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,453.7	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	4,741.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.6	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,741.3	7.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	3.1
Load Factor	0.8
CFM - HTG	2500
CFM - CLG	2500
% OA	35.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	2,100
Heating HRSON	2,464	3,360
C/H HRSON	4,015	5,475
Cooling HRSAB	560	
Heating HRSAB	896	
C/H HRSAB	1,460	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10502
System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,186.8	0.0	
Optimum ST/SP	0.0	440.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	4.7	0.0	0.0	
Night Setback	0.0	0.0	87.5	
Sub Total	4.7	8,626.8	87.5	
Economizer	0.0	1,146.5	0.0	
Ventilation/Recirculation	0.0	614.2	0.0	
DDC Control	0.0	0.0	32.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	4.7	10,387.5	119.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	1500	1500	1500	1500	1500	1500	1500

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	4500
CFM - CLG	4500
% OA	35.00%
% Area	26.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	1,260
Heating HRSON	2,464	2,016
C/H HRSON	4,015	3,285
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	0	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10502

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU2

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	151.7	
Sub Total	10.8	1,012.1	151.7	
Economizer	0.0	2,063.7	0.0	
Ventilation/Recirculation	0.0	1,105.5	22.5	
DDC Control	0.0	0.0	56.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	4,181.3	230.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	6100
CFM - CLG	6100
% OA	35.00%
% Area	36.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	2,100
Heating HRSON	2,464	3,360
C/H HRSON	4,015	5,475
Cooling HRSAB	560	
Heating HRSAB	896	
C/H HRSAB	1,460	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUCHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

31-Mar-95

PAGE 2 OF 2

Bldg Number: 10502

System Type: 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU3

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	19,497.3	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	210.0	
Sub Total	10.8	20,509.4	210.0	
Economizer	0.0	2,797.5	0.0	
Ventilation/Recirculation	0.0	1,498.5	0.0	
DDC Control	0.0	0.0	77.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	24,805.4	287.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	600	600	600	600	600	600	600
Stop Time	2100	2100	2100	2100	2100	2100	2100

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	4000
CFM - CLG	4000
% OA	35.00%
% Area	23.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	2,100
Heating HRSON	2,464	3,360
C/H HRSON	4,015	5,475
Cooling HRSAB	560	
Heating HRSAB	896	
C/H HRSAB	1,460	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10502
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU4

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	15,490.9	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	134.2	
Sub Total	10.8	16,503.0	134.2	
Economizer	0.0	1,834.4	0.0	
Ventilation/Recirculation	0.0	982.6	20.0	
DDC Control	0.0	0.0	49.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	19,320.0	203.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10502

Building Sq.Ft.: 18,199

System Type: 8
System Name: CHILLER AND PUMPS
System Number: WC1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
12	BRICK	EXCHANGE/CLUB	0800-300	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1600	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	73
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	0.8
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,540	3,360
Heating HRSON	2,464	5,376
C/H HRSON	4,015	8,760
Cooling HRSAB	1,820	
Heating HRSAB	2,912	
C/H HRSAB	4,745	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	9.73E-03	9.73E-03
COAUHC	3.73E-03	3.73E-03
HOAOH	46.22	46.22
HOAOHC	28.36	28.36
COAOC	5.73E-03	5.73E-03
COAOHC	2.20E-03	2.20E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	2.98E-04	2.98E-04
ECHC	1.14E-04	1.14E-04
NSUCC	2.13E-03	2.13E-03
NSUHC	1.31E-03	1.31E-03
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+04	1.18E+04
NSC	3.21E+04	3.21E+04
FV	64	64
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

31-Mar-95

PAGE 2 OF 2

Bldg Number: 10502

System Type 8

System Name: CHILLER AND PUMPS

System Number: WC1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	9,797.8	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	10.8	10,809.9	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	698.6	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	11,508.5	0.0	3

ENERGY CALCULATIONS

BUILDING 10506

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10506

Building Sq.Ft.: 18,386

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 30-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
13	BRICK	CLINIC W/O BEDS	0700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	9300
CFM - CLG	11500
% OA	100.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	0.78
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.11E-03	2.11E-03
COAUHC	8.08E-04	8.08E-04
HOAOH	227.68	227.68
HOAOHC	139.72	139.72
COAOC	3.35E-03	3.35E-03
COAOHC	1.29E-03	1.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.77E-04	2.77E-04
NSUCHC	1.70E-04	1.70E-04
DDCCHC	1.32E-04	1.32E-04
DDCCC	3.44E-04	3.44E-04
DSC	3.81E+03	3.81E+03
NSC	2.59E+04	2.59E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 30-Mar-95
PAGE 2 OF 2

Bldg Number: 10506
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	78,056.1	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	10.8	0.0	0.0	
Night Setback	0.0	0.0	71.5	
Sub Total	10.8	79,068.1	71.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	13,613.8	10.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	10.8	92,682.0	82.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10506

Building Sq.Ft.: 18,386

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE2

EMC NO.: 1406-006

DATE: 30-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
13	BRICK	CLINIC W/O BEDS	0700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.1836
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.11E-03	2.11E-03
COAUHC	8.08E-04	8.08E-04
HOAOH	227.68	227.68
HOAOHC	139.72	139.72
COAOC	3.35E-03	3.35E-03
COAOHC	1.29E-03	1.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.77E-04	2.77E-04
NSUCHC	1.70E-04	1.70E-04
DDCCHC	1.32E-04	1.32E-04
DDCCC	3.44E-04	3.44E-04
DSC	3.81E+03	3.81E+03
NSC	2.59E+04	2.59E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 30-Mar-95
PAGE 2 OF 2

Bldg Number: 10506
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,813.5	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	2,975.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.4	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,975.5	1.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10506

Building Sq.Ft.: 18,386

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE1

EMC NO.: 1406-006

DATE: 30-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
13	BRICK	CLINIC W/O BEDS	0700-1600	MON-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	85.00%
TON CAPC.	0
MBTU CAPC.	0.46
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.11E-03	2.11E-03
COAUHC	8.08E-04	8.08E-04
HOAOH	227.68	227.68
HOAOHC	139.72	139.72
COAOC	3.35E-03	3.35E-03
COAOHC	1.29E-03	1.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.77E-04	2.77E-04
NSUCHC	1.70E-04	1.70E-04
DDCCHC	1.32E-04	1.32E-04
DDCCC	3.44E-04	3.44E-04
DSC	3.81E+03	3.81E+03
NSC	2.59E+04	2.59E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 30-Mar-95
PAGE 2 OF 2

Bldg Number: 10506
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,246.4	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	405.4	
Sub Total	0.0	2,375.8	405.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	59.6	
HW OA Reset	0.0	0.0	3.4	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,375.8	468.3	3

ENERGY CALCULATIONS

BUILDING 10510

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10510

Building Sq.Ft.: 12,450

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10510

Building Sq.Ft.: 12,450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10510

Building Sq.Ft.: 12,450

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10510

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10510

Building Sq.Ft.: 12,450

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10510

System Type: 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.3	3

ENERGY CALCULATIONS

BUILDING 10512

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,512

Building Sq.Ft.: 52,266

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,512

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,512

Building Sq.Ft.: 52,266

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,512

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type: 14
System Name: VENTILATION
System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type 14

System Name: VENTILATION

System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type 14
System Name: VENTILATION
System Number: AHU-2

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10512
System Type 14
System Name: VENTILATION
System Number: AHU-2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type 14

System Name: VENTILATION

System Number: AHU3

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type 14

System Name: VENTILATION

System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type 14

System Name: VENTILATION

System Number: AHU-4

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4779
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type 14

System Name: VENTILATION

System Number: AHU-4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	110.2	
Sub Total	0.0	1,683.3	110.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	123.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	110.2	
Sub Total	0.0	1,683.3	110.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	123.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	110.2	
Sub Total	0.0	1,683.3	110.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	123.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 17,770

System Type	1
System Name:	H&V UNIT WITHOUT RETURN FAN
System Number:	AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSon	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10512
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	110.2	
Sub Total	0.0	1,683.3	110.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	123.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 34,496

System Type	1
System Name:	H&V UNIT WITHOUT RETURN FAN
System Number:	AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10512

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	80.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	80.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10512

Building Sq.Ft.: 34,496

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10232

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	80.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	80.0	3

ENERGY CALCULATIONS

BUILDING 10514

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,514

Building Sq.Ft.: 45,719

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,514

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,514

Building Sq.Ft.: 45,719

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,514

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10514

Building Sq.Ft.: 11,430

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10514

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.5	
Sub Total	0.0	1,683.3	94.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10514

Building Sq.Ft.: 11,430

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10514

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.5	
Sub Total	0.0	1,683.3	94.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10514

Building Sq.Ft.: 11,430

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10514
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.5	
Sub Total	0.0	1,683.3	94.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10514

Building Sq.Ft.: 34,289

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1

LOOK-UP VALUE

EFFHP	65.00%	65.00%
-------	--------	--------

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10514

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10514

Building Sq.Ft.: 34,289

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10514

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.7	3

ENERGY CALCULATIONS

BUILDING 10520

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10520

Building Sq.Ft.: 12,450

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10520

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10520

Building Sq.Ft.: 12,450

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DCCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10520

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10520

Building Sq.Ft.: 12,450

System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10520
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10520

Building Sq.Ft.: 12,450

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10520
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.3	3

ENERGY CALCULATIONS

BUILDING 10522

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,522

Building Sq.Ft.: 43,886

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,522
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 43,886

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10522

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	129.4	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	129.4	4.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 10,972

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10522
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.7	
Sub Total	0.0	1,683.3	90.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 10,972

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10522
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.7	
Sub Total	0.0	1,683.3	90.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 10,972

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10522
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.7	
Sub Total	0.0	1,683.3	90.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 32,915

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10522

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	78.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	78.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10522

Building Sq.Ft.: 32,915

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10522
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	78.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	78.4	3

ENERGY CALCULATIONS

BUILDING 10524

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,524

Building Sq.Ft.: 45,746

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,524
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,524

Building Sq.Ft.: 45,746

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,524
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10524

Building Sq.Ft.: 11,437

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10524

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.6	
Sub Total	0.0	1,683.3	94.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10524

Building Sq.Ft.: 11,437

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10524

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.6	
Sub Total	0.0	1,683.3	94.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10524

Building Sq.Ft.: 11,437

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10524
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	94.6	
Sub Total	0.0	1,683.3	94.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	105.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10524

Building Sq.Ft.: 34,310

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10524

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10524

Building Sq.Ft.: 34,310

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10524

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.7	3

ENERGY CALCULATIONS

BUILDING 10550

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10550

Building Sq.Ft.: 15,560

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	8000
CFM - CLG	0
% OA	100.00%
% Area	17.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAV	840	
Heating HRSAV	1,344	
C/H HRSAV	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,789.6	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	174.4	
Sub Total	0.0	12,801.7	174.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	63.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,801.7	237.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10550

Building Sq.Ft.: 15,560

System Type 2

System Name: H&V UNIT

System Number: AHU2

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	8
Load Factor	0.8
CFM - HTG	5265
CFM - CLG	0
% OA	25.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550

System Type: 2

System Name: H&V UNIT

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	14,042.8	0.0	
Optimum ST/SP	0.0	1,079.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	248.4	
Sub Total	0.0	15,122.3	248.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	89.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	15,122.3	338.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10550

Building Sq.Ft.: 15,560

System Type 2

System Name: H&V UNIT

System Number: AHU3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	4670
CFM - CLG	0
% OA	100.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAV	938	
Heating HRSAV	1,501	
C/H HRSAV	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550
System Type 2
System Name: H&V UNIT
System Number: AHU3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,001.1	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	219.2	
Sub Total	0.0	18,308.0	219.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	18,308.0	298.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10550

Building Sq.Ft.: 15,560

System Type 2

System Name: H&V UNIT

System Number: AHU4

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/MLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	7430
CFM - CLG	0
% OA	5.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550

System Type: 2

System Name: H&V UNIT

System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,236.9	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	350.7	
Sub Total	0.0	27,177.0	350.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	126.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	27,177.0	477.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10550

Building Sq.Ft.: 15,560

System Type 2

System Name: H&V UNIT

System Number: AHU5

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6
Load Factor	0.8
CFM - HTG	3145
CFM - CLG	0
% OA	5.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550
System Type: 2
System Name: H&V UNIT
System Number: AHU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	10,725.7	0.0	
Optimum ST/SP	0.0	824.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	146.1	
Sub Total	0.0	11,550.2	146.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	52.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	11,550.2	198.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10550

Building Sq.Ft.: 15,560

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	600
CFM - CLG	0
% OA	0.00%
% Area	1.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAV	840	
Heating HRSAV	1,344	
C/H HRSAV	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,614.1	0.0	
Optimum ST/SP	0.0	567.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.4	
Sub Total	0.0	7,181.9	23.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	8.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	7,181.9	31.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10550

Building Sq.Ft.: 15,560

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	7.40%
TON CAPC.	0
MBTU CAPC.	1.5064
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAV	840	
Heating HRSAV	1,344	
C/H HRSAV	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10550

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,349.5	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	108.1	
Sub Total	0.0	3,637.0	108.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	39.1	
HW OA Reset	0.0	0.0	11.1	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,637.0	158.3	3

ENERGY CALCULATIONS

BUILDING 10570

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type: 2

System Name: H&V UNIT

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.9	
Sub Total	0.0	83,884.9	23.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	30.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,828

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 2

System Name: H&V UNIT

System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.9	
Sub Total	0.0	101,035.1	23.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	30.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10570

Building Sq.Ft.: 25,827

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 2

System Name: H&V UNIT

System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.9	
Sub Total	0.0	83,884.9	23.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	30.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10570
System Type: 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.0	
Sub Total	0.0	83,884.9	12.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	15.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.3	
Sub Total	0.0	56,826.3	14.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.:

25,827

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

MAU-2

EMC NO.: 1406-006

DATE:

05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.2	
Sub Total	0.0	56,826.3	7.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10570

Building Sq.Ft.: 25,827

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.3	
Sub Total	0.0	56,826.3	14.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10570

Building Sq.Ft.: 25,827

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10570
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	14.3	
Sub Total	0.0	56,826.3	14.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	18.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10570

Building Sq.Ft.: 25,827

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10570
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.2	
Sub Total	0.0	56,826.3	7.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.0	
Sub Total	0.0	56,826.3	12.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	15.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.:

25,827

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	4.8	
Sub Total	0.0	29,644.0	4.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	6.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	57.4	
Sub Total	0.0	12,616.7	57.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	14.7	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	98.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10570

Building Sq.Ft.: 25,827

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10570
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10570

Building Sq.Ft.: 25,827

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10570

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10580

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type: 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	100.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 2

System Name: H&V UNIT

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	25.3	
Sub Total	0.0	83,884.9	25.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	31.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 2

System Name: H&V UNIT

System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	25.3	
Sub Total	0.0	101,035.1	25.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	31.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10580
System Type: 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	25.3	
Sub Total	0.0	83,884.9	25.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	31.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 2

System Name: H&V UNIT

System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.6	
Sub Total	0.0	83,884.9	12.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	15.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10580
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.2	
Sub Total	0.0	56,826.3	15.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCM/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.6	
Sub Total	0.0	56,826.3	7.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.2	
Sub Total	0.0	56,826.3	15.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10580
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.2	
Sub Total	0.0	56,826.3	15.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	19.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.6	
Sub Total	0.0	56,826.3	7.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	9.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.6	
Sub Total	0.0	56,826.3	12.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	15.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	5.1	
Sub Total	0.0	29,644.0	5.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	6.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	60.7	
Sub Total	0.0	12,616.7	60.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	15.5	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	102.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10580

Building Sq.Ft.: 27,310

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10580

Building Sq.Ft.: 27,310

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10580

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10610

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10610

Building Sq.Ft.: 12,452

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10610

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10610

Building Sq.Ft.: 12,452

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10610

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10610

Building Sq.Ft.: 12,452

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10610

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10610

Building Sq.Ft.: 12,452

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10610
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.4	3

ENERGY CALCULATIONS

BUILDING 10612

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,612

Building Sq.Ft.: 53,892

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,612

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,612

Building Sq.Ft.: 53,892

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,612

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 14

System Name: VENTILATION

System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10612
System Type 14
System Name: VENTILATION
System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 14

System Name: VENTILATION

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10612
System Type 14
System Name: VENTILATION
System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 14

System Name: VENTILATION

System Number: AHU3

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10612
System Type: 14
System Name: VENTILATION
System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 14

System Name: VENTILATION

System Number: AHU-4

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4779
CFM - CLG	0
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 12-Apr-95

PAGE 2 OF 2

Bldg Number: 10612
System Type: 14
System Name: VENTILATION
System Number: AHU-4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10612
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	113.6	
Sub Total	0.0	1,683.3	113.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	127.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10612
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	113.6	
Sub Total	0.0	1,683.3	113.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	127.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10612

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	113.6	
Sub Total	0.0	1,683.3	113.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	127.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 18,323

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10612
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	113.6	
Sub Total	0.0	1,683.3	113.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	127.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10612

Building Sq.Ft.: 35,569

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10612

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	83.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	83.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10612

Building Sq.Ft.: 35,569

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10512
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	80.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	80.7	3

ENERGY CALCULATIONS

BUILDING 10614

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,614

Building Sq.Ft.: 44,510

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,614
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,614

Building Sq.Ft.: 44,510

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,614
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10614

Building Sq.Ft.: 11,128

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10614
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	92.0	
Sub Total	0.0	1,683.3	92.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	103.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10614

Building Sq.Ft.: 11,128

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10614

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	92.0	
Sub Total	0.0	1,683.3	92.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	103.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10614

Building Sq.Ft.: 11,128

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10614
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	92.0	
Sub Total	0.0	1,683.3	92.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	11.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	103.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10614

Building Sq.Ft.: 33,383

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAH	0.00	0.00
HOAHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAH	0.00	0.00
HOAHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10614
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10614

Building Sq.Ft.: 33,383

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10614
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	79.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	79.5	3

ENERGY CALCULATIONS

BUILDING 10620

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10620

Building Sq.Ft.: 13,225

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10620

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	173.5	
Sub Total	0.0	8,501.7	173.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	186.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10620

Building Sq.Ft.: 13,225

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10620
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	33.0	
Sub Total	0.0	4,791.4	33.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	35.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10620

Building Sq.Ft.: 13,225

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10620

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10620

Building Sq.Ft.: 13,225

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10620

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	619.6	
Sub Total	0.0	2,397.8	619.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	48.0	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	668.4	3

ENERGY CALCULATIONS

BUILDING 10622

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 52,990

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCW/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0 *
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,900	3,360
Heating HRSON	3,040	5,376
C/H HRSON	4,954	8,760
Cooling HRSAB	1,460	
Heating HRSAB	2,336	
C/H HRSAB	3,806	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

*ESTIMATED PUMP ON 50% OF UNOCCUPIED HOURS

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95
PAGE 2 OF 2

Bldg Number: 10622
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,572.8	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	3,860.3	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,860.3	2.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,622

Building Sq.Ft.: 52,990

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,622

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type 14

System Name: VENTILATION

System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUC	0.00	0.00
HOAUC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUC	0.00E+00	0.00E+00
HOAOC	220.75	220.75
HOAOC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10622
System Type: 14
System Name: VENTILATION
System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type: 14
System Name: VENTILATION
System Number: AHU-2

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 12-Apr-95
PAGE 2 OF 2

Bldg Number: 10622
System Type 14
System Name: VENTILATION
System Number: AHU-2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type: 14
System Name: VENTILATION
System Number: AHU3

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY. ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 14

System Name: VENTILATION

System Number: AHU3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type: 14 VENTILATION

System Name: VENTILATION

System Number: AHU4

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 14

System Name: VENTILATION

System Number: AHU4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	111.8	
Sub Total	0.0	1,683.3	111.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	125.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	111.8	
Sub Total	0.0	1,683.3	111.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	125.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	111.8	
Sub Total	0.0	1,683.3	111.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	125.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10622

Building Sq.Ft.: 18,017

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	111.8	
Sub Total	0.0	1,683.3	111.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	125.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10622

Building Sq.Ft.: 34,973

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10622

Building Sq.Ft.:

34,973

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

AHU11

EMC NO.: 1406-006

DATE:

02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10622

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	81.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	81.9	3

ENERGY CALCULATIONS

BUILDING 10630

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10630

Building Sq.Ft.: 12,452

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.40%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

28-Mar-95

PAGE 2 OF 2

Bldg Number: 10630

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	166.4	
Sub Total	0.0	8,501.7	166.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	179.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10630

Building Sq.Ft.: 12,452

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	3.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10630

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	28.0	
Sub Total	0.0	4,791.4	28.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	30.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10630

Building Sq.Ft.: 12,452

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE2

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10630

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10630

Building Sq.Ft.: 12,452

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

28-Mar-95

PAGE 2 OF 2

Bldg Number: 10630

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

ENERGY CALCULATIONS

BUILDING 10632

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,632

Building Sq.Ft.: 51,794

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.5123
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,632

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,632

Building Sq.Ft.: 51,794

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9801
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,632

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	7.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	7.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type: 14
System Name: VENTILATION
System Number: AHU-1

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 12-Apr-95

PAGE 2 OF 2

Bldg Number: 10632
System Type 14
System Name: VENTILATION
System Number: AHU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSVA	2,060	
Heating HRSVA	3,296	
C/H HRSVA	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUI	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10632

System Type 14

System Name: VENTILATION

System Number: AHU2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU-3

EMC NO.: 1406-006

DATE: 12-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK V	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4566
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRS AV	2,060	
Heating HRS AV	3,296	
C/H HRS AV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

12-Apr-95

PAGE 2 OF 2

Bldg Number: 10632
System Type 14
System Name: VENTILATION
System Number: AHU-3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	5,092.0	0.0	0

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 14

System Name: VENTILATION

System Number: AHU4

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4779
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10632
System Type 14
System Name: VENTILATION
System Number: AHU4

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,666.1	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,092.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,092.0	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10632
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU7

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95

PAGE 2 OF 2

Bldg Number: 10632

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1

LOOK-UP VALUE

EFFHP	65.00%	65.00%
-------	--------	--------

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10632
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10632

Building Sq.Ft.: 17,610

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU9

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY,ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	750
CFM - CLG	0
% OA	100.00%
% Area	12.75%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10632

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	109.2	
Sub Total	0.0	1,683.3	109.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	13.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	122.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10632

Building Sq.Ft.: 34,184

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	1860
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10632

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	83.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	83.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10632

Building Sq.Ft.: 34,184

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1350
CFM - CLG	0
% OA	100.00%
% Area	19.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10632

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU11

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	80.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	80.0	3

ENERGY CALCULATIONS

BUILDING 10640

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10640

Building Sq.Ft.: 12,452

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1230
CFM - CLG	0
% OA	100.00%
% Area	21.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10640

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	8,214.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	163.3	
Sub Total	0.0	8,501.7	163.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	12.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,501.7	176.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10640

Building Sq.Ft.: 12,452

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	210
CFM - CLG	0
% OA	100.00%
% Area	4.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10640
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,629.4	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.1	
Sub Total	0.0	4,791.4	31.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,791.4	33.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10640

Building Sq.Ft.: 12,452

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.2602
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

04-Apr-95

PAGE 2 OF 2

Bldg Number: 10640

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	5,041.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,328.6	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,328.6	1.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10640

Building Sq.Ft.:

12,452

System Type

12

System Name:

BASEBOARD RADIATION

System Number:

HE2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
17	BRICK	BN HQ BLDG	0600-1700	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	75.00%
TON CAPC.	0
MBTU CAPC.	0.1117
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	257.00	257.00
HOAOHC	158.00	158.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	4.84E+03	4.84E+03
NSC	6.25E+04	6.25E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10640
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,268.5	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	583.3	
Sub Total	0.0	2,397.8	583.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.2	
HW OA Reset	0.0	0.0	0.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,397.8	629.4	3

ENERGY CALCULATIONS

BUILDING 10642

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,642

Building Sq.Ft.: 43,790

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,642

System Type: 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,642

Building Sq.Ft.: 43,790

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,642

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10642

Building Sq.Ft.: 10,948

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10642

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.5	
Sub Total	0.0	1,683.3	90.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10642

Building Sq.Ft.: 10,948

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10642

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.5	
Sub Total	0.0	1,683.3	90.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10642

Building Sq.Ft.: 10,948

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10642
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	90.5	
Sub Total	0.0	1,683.3	90.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	101.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10642

Building Sq.Ft.: 32,843

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10642

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	78.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	78.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10642

Building Sq.Ft.: 32,843

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10642

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	78.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	78.2	3

ENERGY CALCULATIONS

BUILDING 10644

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,644

Building Sq.Ft.: 40,864

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE-1

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.3875
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95

PAGE 2 OF 2

Bldg Number: 10,644
System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HE-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	287.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	287.5	2.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10,644

Building Sq.Ft.: 40,864

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE-2

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.6683
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 01-Apr-95
PAGE 2 OF 2

Bldg Number: 10,644
System Type: 12
System Name: BASEBOARD RADIATION
System Number: HE-2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10644

Building Sq.Ft.: 10,216

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU1

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10644

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	84.5	
Sub Total	0.0	1,683.3	84.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	94.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10644

Building Sq.Ft.: 10,216

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU2

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10644

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	84.5	
Sub Total	0.0	1,683.3	84.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	94.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10644

Building Sq.Ft.: 10,216

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU4

EMC NO.: 1406-006

DATE: 02-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
14	BRICK	ADM & SUPPLY, ENL BRK	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	770
CFM - CLG	0
% OA	100.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	220.75	220.75
HOAOHC	110.07	110.07
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DCCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	5.84E+03	5.84E+03
NSC	4.86E+04	4.86E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 02-Apr-95
PAGE 2 OF 2

Bldg Number: 10644
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	1,626.4	0.0	
Optimum ST/SP	0.0	56.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	84.5	
Sub Total	0.0	1,683.3	84.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	1,683.3	94.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10644

Building Sq.Ft.: 30,648

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCW/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1300
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10644

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU5

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	73.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	73.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10644

Building Sq.Ft.: 30,648

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

EMC NO.: 1406-006

DATE: 01-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
15	BRICK	ADM & SUPPLY, ENL BRK	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	1060
CFM - CLG	0
% OA	100.00%
% Area	16.70%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.40E+04	1.40E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

02-Apr-95

PAGE 2 OF 2

Bldg Number: 10644

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

HEATING AND VENTILATING SYSTEM	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	73.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	73.0	3

ENERGY CALCULATIONS

BUILDING 10650

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10650

Building Sq.Ft.: 12,578

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	8000
CFM - CLG	0
% OA	100.00%
% Area	17.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10650

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,789.6	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	174.4	
Sub Total	0.0	12,801.7	174.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	63.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,801.7	237.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10650

Building Sq.Ft.: 12,578

System Type 2

System Name: H&V UNIT

System Number: AHU2

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	8
Load Factor	0.8
CFM - HTG	5265
CFM - CLG	0
% OA	25.00%
% Area	17.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAV	938	
Heating HRSAV	1,501	
C/H HRSAV	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10650
System Type: 2
System Name: H&V UNIT
System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	14,042.8	0.0	
Optimum ST/SP	0.0	1,079.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	200.8	
Sub Total	0.0	15,122.3	200.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	72.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	15,122.3	273.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10650

Building Sq.Ft.: 12,578

System Type 2

System Name: H&V UNIT

System Number: AHU3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	4670
CFM - CLG	0
% OA	100.00%
% Area	15.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10650
System Type 2
System Name: H&V UNIT
System Number: AHU3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,001.1	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	177.2	
Sub Total	0.0	18,308.0	177.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	64.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	18,308.0	241.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10650

Building Sq.Ft.: 12,578

System Type 2

System Name: H&V UNIT

System Number: AHU4

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	7430
CFM - CLG	0
% OA	5.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10650
System Type 2
System Name: H&V UNIT
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,236.9	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	283.5	
Sub Total	0.0	27,177.0	283.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	102.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	27,177.0	385.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10650

Building Sq.Ft.: 12,578

System Type 2

System Name: H&V UNIT

System Number: AHU5

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	1930	1930	1930	1930	1930	1930	1930

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6
Load Factor	0.8
CFM - HTG	3145
CFM - CLG	0
% OA	5.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,422	3,360
Heating HRSON	3,875	5,376
C/H HRSON	6,314	8,760
Cooling HRSAB	938	
Heating HRSAB	1,501	
C/H HRSAB	2,445	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10650
System Type 2
System Name: H&V UNIT
System Number: AHU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	10,725.7	0.0	
Optimum ST/SP	0.0	824.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	118.1	
Sub Total	0.0	11,550.2	118.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	42.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	11,550.2	160.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10650

Building Sq.Ft.: 12,578

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HE1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	7.40%
TON CAPC.	0
MBTU CAPC.	1.5064
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAV	840	
Heating HRSAV	1,344	
C/H HRSAV	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10650
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HE1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,349.5	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	87.4	
Sub Total	0.0	3,637.0	87.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	31.6	
HW OA Reset	0.0	0.0	11.1	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,637.0	130.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10650

Building Sq.Ft.: 12,578

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
16	BRICK	ENK PERS DINNING	0400-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	400	400	400	400	400	400	400
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	600
CFM - CLG	0
% OA	0.00%
% Area	1.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	2,520	3,360
Heating HRSON	4,032	5,376
C/H HRSON	6,570	8,760
Cooling HRSAB	840	
Heating HRSAB	1,344	
C/H HRSAB	2,190	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	39.67	39.67
HOAOHC	24.34	24.34
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	3.39E+04	3.39E+04
NSC	9.39E+04	9.39E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10650
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,614.1	0.0	
Optimum ST/SP	0.0	567.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	18.9	
Sub Total	0.0	7,181.9	18.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	7,181.9	25.7	3

ENERGY CALCULATIONS

BUILDING 10660

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type: 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 2
System Name: H&V UNIT
System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	38.9	
Sub Total	0.0	83,884.9	38.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	9.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	48.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 10660
System Type 2
System Name: H&V UNIT
System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	38.9	
Sub Total	0.0	101,035.1	38.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	9.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	48.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10660

Building Sq.Ft.: 41,968

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	38.9	
Sub Total	0.0	83,884.9	38.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	9.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	48.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10660

Building Sq.Ft.: 41,968

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	19.4	
Sub Total	0.0	83,884.9	19.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	24.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10660

Building Sq.Ft.: 41,968

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KCW/LC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.3	
Sub Total	0.0	56,826.3	23.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	29.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10660
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	11.7	
Sub Total	0.0	56,826.3	11.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	14.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10660
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.3	
Sub Total	0.0	56,826.3	23.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	29.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	23.3	
Sub Total	0.0	56,826.3	23.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	29.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	11.7	
Sub Total	0.0	56,826.3	11.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	14.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10660

Building Sq.Ft.: 41,968

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	19.4	
Sub Total	0.0	56,826.3	19.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	24.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.:

41,968

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

MAU-7

EMC NO.: 1406-006

DATE:

05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.8	
Sub Total	0.0	29,644.0	7.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	9.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10660
System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	93.3	
Sub Total	0.0	12,616.7	93.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	23.8	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	143.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10660

Building Sq.Ft.: 41,968

System Type: 9
System Name: CONVERTER AND PUMPS
System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10660

Building Sq.Ft.: 41,968

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10660
System Type 9
System Name: CONVERTER AND PUMPS
System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10670

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 2

System Name: H&V UNIT

System Number: HV1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	11135
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type: 2

System Name: H&V UNIT

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	40.3	
Sub Total	0.0	83,884.9	40.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	50.6	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 2

System Name: H&V UNIT

System Number: HV2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	27.5
Load Factor	0.8
CFM - HTG	11410
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	89.40% 89.40%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10670
System Type: 2
System Name: H&V UNIT
System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,585.7	0.0	
Optimum ST/SP	0.0	3,449.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	40.3	
Sub Total	0.0	101,035.1	40.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	101,035.1	50.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 2

System Name: H&V UNIT

System Number: HV3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	6020
CFM - CLG	0
% OA	33.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670
System Type: 2
System Name: H&V UNIT
System Number: HV3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	40.3	
Sub Total	0.0	83,884.9	40.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	10.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	50.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 2

System Name: H&V UNIT

System Number: HV4

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	22.5
Load Factor	0.8
CFM - HTG	4090
CFM - CLG	0
% OA	33.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670
System Type 2
System Name: H&V UNIT
System Number: HV4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	81,021.0	0.0	
Optimum ST/SP	0.0	2,863.9	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	20.1	
Sub Total	0.0	83,884.9	20.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	83,884.9	25.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10670

Building Sq.Ft.: 43,519

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	18150
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
KW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.2	
Sub Total	0.0	56,826.3	24.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	30.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9200
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.1	
Sub Total	0.0	56,826.3	12.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	15.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.2	
Sub Total	0.0	56,826.3	24.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	30.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	24.2	
Sub Total	0.0	56,826.3	24.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	6.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	30.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95
PAGE 2 OF 2

Bldg Number: 10670
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	12.1	
Sub Total	0.0	56,826.3	12.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	15.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-6

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS	REQUIRED	PRESENT
CALCULATIONS	HR/YR	HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	20.1	
Sub Total	0.0	56,826.3	20.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	25.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	6840
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	8.1	
Sub Total	0.0	29,644.0	8.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	10.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 12
System Name: BASEBOARD RADIATION
System Number: HTP1

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	3.587
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUHC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	96.7	
Sub Total	0.0	12,616.7	96.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	24.7	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	147.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10670

Building Sq.Ft.: 43,519

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 31-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 31-Mar-95

PAGE 2 OF 2

Bldg Number: 10670

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10680

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10680

Building Sq.Ft.: 39,679

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16920
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10680

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	11.0	
Sub Total	0.0	56,826.3	11.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	13.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	22.0	
Sub Total	0.0	56,826.3	22.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	27.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10680

Building Sq.Ft.:

39,679

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

MAU-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	20000
CFM - CLG	0
% OA	100.00%
% Area	6.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRS AV	2,040	
Heating HRS AV	3,264	
C/H HRS AV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	22.0	
Sub Total	0.0	56,826.3	22.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	5.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	27.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10680

Building Sq.Ft.: 39,679

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	10000
CFM - CLG	0
% OA	100.00%
% Area	3.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	11.0	
Sub Total	0.0	56,826.3	11.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	13.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10680

Building Sq.Ft.:

39,679

System Type

1

System Name:

H&V UNIT WITHOUT RETURN FAN

System Number:

MAU6

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10680
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	54,886.2	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	18.4	
Sub Total	0.0	56,826.3	18.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	56,826.3	23.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10680

Building Sq.Ft.: 39,679

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU-7

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	16100
CFM - CLG	0
% OA	100.00%
% Area	2.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSVA	2,040	
Heating HRSVA	3,264	
C/H HRSVA	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU-7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,632.0	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	7.3	
Sub Total	0.0	29,644.0	7.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	1.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	29,644.0	9.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG:

10680

Building Sq.Ft.:

39,679

System Type

12

System Name:

BASEBOARD RADIATION

System Number:

HTP1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS		INPUT
Motor HP		5
Load Factor		0.8
CFM - HTG		0
CFM - CLG		0
% OA		0.00%
% Area		24.00%
TON CAPC.		0
MBTU CAPC.		3.587
kW/Ton		0
MOSON		7
EFF		1
LOOK-UP VALUE		
EFFHP	81.60%	81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type 12

System Name: BASEBOARD RADIATION

System Number: HTP1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	88.2	
Sub Total	0.0	12,616.7	88.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	22.5	
HW OA Reset	0.0	0.0	26.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	137.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10680

Building Sq.Ft.: 39,679

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.62
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAV	2,040	
Heating HRSAV	3,264	
C/H HRSAV	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	34.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	34.2	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10680

Building Sq.Ft.: 39,679

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
18	BRICK	VEH MNT SHOP	0700-1900	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	700
Stop Time	0	1600	1600	1600	1600	1600	1600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	4.258
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,320	3,360
Heating HRSON	2,112	5,376
C/H HRSON	3,441	8,760
Cooling HRSAB	2,040	
Heating HRSAB	3,264	
C/H HRSAB	5,319	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	15.77	15.77
HOAOHC	9.68	9.68
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.36E+03	2.36E+03
NSC	9.26E+03	9.26E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10680

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HTP3

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	11,929.6	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	12,616.7	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	31.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,616.7	31.5	3

ENERGY CALCULATIONS

BUILDING 10690

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU-1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	20
Load Factor	0.8
CFM - HTG	11000
CFM - CLG	11000
% OA	9.00%
% Area	43.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	0
EFF	1
LOOK-UP VALUE	
EFFHP	88.10% 88.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 4

System Name: SINGLE ZONE AHU

System Number: AHU-1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	69,236.5	0.0	
Optimum ST/SP	0.0	2,545.7	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	27.1	0.0	0.0	
Night Setback	0.0	0.0	685.2	
Sub Total	27.1	71,782.2	685.2	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	1.5	1.0	
DDC Control	0.0	0.0	100.0	
HWV OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	27.1	71,783.7	786.2	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

System Type	1
System Name:	H&V UNIT WITHOUT RETURN FAN
System Number:	HV1

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	2040
CFM - CLG	0
% OA	33.00%
% Area	10.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,404.6	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	167.0	
Sub Total	0.0	4,566.7	167.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.7	
DDC Control	0.0	0.0	24.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,566.7	192.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV2

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	3300
CFM - CLG	0
% OA	100.00%
% Area	34.20%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,815.4	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	538.7	
Sub Total	0.0	8,103.0	538.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	78.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,103.0	617.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 11

System Name: CONDENSING UNIT

System Number: DC1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	31.75
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 11

System Name: CONDENSING UNIT

System Number: DC1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	303.8	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	303.8	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 11

System Name: CONDENSING UNIT

System Number: DC3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	11.2
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10690
System Type 11
System Name: CONDENSING UNIT
System Number: DC3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	107.2	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	107.2	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type: 11
System Name: CONDENSING UNIT
System Number: CU-1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	25.3
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10690
System Type 11
System Name: CONDENSING UNIT
System Number: CU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	242.1	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	242.1	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type: 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	5400
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,669.3	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,095.1	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,095.1	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type: 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC3

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	5400
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 06-Apr-95
PAGE 2 OF 2

Bldg Number: 10690
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC3

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,669.3	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,095.1	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,095.1	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC5

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	
CFM - CLG	5400
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC5

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,669.3	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	5,095.1	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	5,095.1	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC7

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4300
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC7

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,180.6	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	3,468.1	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,468.1	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC8

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4300
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC8

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	3,180.6	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	3,468.1	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	3,468.1	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type: 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AC9

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	8100
% OA	100.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRS AV	1,960	
Heating HRS AV	3,136	
C/H HRS AV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCHC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	6	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AC9

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,508.1	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	8,195.2	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,195.2	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10690

Building Sq.Ft.: 26,400

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX1

EMC NO.: 1406-006

DATE: 06-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
10	BRICK	DIV CMD/CNTRL BUILDING	600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.59
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSVA	0	
Heating HRSVA	0	
C/H HRSVA	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	2.17E-05	2.17E-05
COAUHC	8.32E-06	8.32E-06
HOAOH	14.77	14.77
HOAOHC	9.07	9.07
COAOC	2.10E-05	2.10E-05
COAOHC	8.04E-06	8.04E-06
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	1.26E-05	1.26E-05
NSUCC	7.74E-06	7.74E-06
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	8.71E+03	8.71E+03
NSC	5.97E+04	5.97E+04
FV	0	6
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

06-Apr-95

PAGE 2 OF 2

Bldg Number: 10690

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	4.4	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	4.4	3

ENERGY CALCULATIONS

BUILDING 10710

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10710

Building Sq.Ft.: 5,900

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV1

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	90.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 10710

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	21.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	21.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10710

Building Sq.Ft.: 5,900

System Type 9

System Name: CONVERTER AND PUMPS

System Number: C1

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.226
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95

PAGE 2 OF 2

Bldg Number: 10710

System Type 9

System Name: CONVERTER AND PUMPS

System Number: C1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	1.7	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	1.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10710

Building Sq.Ft.: 5,900

System Type: 12
System Name: BASEBOARD RADIATION
System Number: RAD

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	10.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 10710

System Type 12

System Name: BASEBOARD RADIATION

System Number: RAD

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	2.4	3

ENERGY CALCULATIONS

BUILDING 10715

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 12,020

System Type 12
System Name: BASEBOARD RADIATION
System Number: HX1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
20	BRICK	POST SAFETY/LEA 2ND F	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1600	1600	1600	1600	1600	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	18.00%
TON CAPC.	0
MBTU CAPC.	0.96
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,100	3,360
Heating HRSON	1,760	5,376
C/H HRSON	2,868	8,760
Cooling HRSAV	2,260	
Heating HRSAV	3,616	
C/H HRSAV	5,892	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	196.36	196.36
HOAOHC	97.91	97.91
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+03	1.18E+03
NSC	2.16E+04	2.16E+04
FV	321	321
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

28-Mar-95

PAGE 2 OF 2

Bldg Number: 10715

System Type 12

System Name: BASEBOARD RADIATION

System Number: HX1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	15,859.4	0.0	
Optimum ST/SP	0.0	824.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	46.7	
Sub Total	0.0	16,683.9	46.7	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	2.6	
HW OA Reset	0.0	0.0	7.1	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	16,683.9	56.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 20,577

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HVU-1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	7760
CFM - CLG	0
% OA	40.59%
% Area	24.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95
PAGE 2 OF 2

Bldg Number: 10715
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HVU-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	20.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	20.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 20,577

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HVU-2

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	8230
CFM - CLG	0
% OA	16.04%
% Area	60.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95
PAGE 2 OF 2

Bldg Number: 10715
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HVU-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	50.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	50.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 12,020

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HVU-3

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
20	BRICK	POST SAFETY/LEA 2ND F	0600-1700	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1700	1700	1700	1700	1700	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	9040
CFM - CLG	0
% OA	11.06%
% Area	82.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	196.36	196.36
HOAOHC	97.91	97.91
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.18E+03	1.18E+03
NSC	2.16E+04	2.16E+04
FV	321	321
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10715

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HVU-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	55,424.3	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	213.0	
Sub Total	0.0	57,364.4	213.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	51.3	
DDC Control	0.0	0.0	11.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	57,364.4	275.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 20,577

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX2

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	8.40%
TON CAPC.	0
MBTU CAPC.	0.8418
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10715

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	162.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	162.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	7.0	
HW OA Reset	0.0	0.0	6.2	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	162.0	13.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10715

Building Sq.Ft.: 20,577

System Type 4
System Name: SINGLE ZONE AHU
System Number: ACU-1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
19	BRICK	POST SAFETY/LEA 1ST FL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.33
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	100.00%
% Area	5.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	3.67E-07	3.67E-07
ECHC	1.23E-07	1.23E-07
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	6.04E-06	6.04E-06
DDCCC	1.81E-05	1.81E-05
DSC	4.06E+03	4.06E+03
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10715
System Type 4
System Name: SINGLE ZONE AHU
System Number: ACU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.6	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.6	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	4.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.6	0.0	4.2	3

ENERGY CALCULATIONS

BUILDING 10730

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU1

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	30
Load Factor	0.8
CFM - HTG	19350
CFM - CLG	19350
% OA	17.00%
% Area	5.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	90.20% 90.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAV	1,680	
Heating HRSAV	2,688	
C/H HRSAV	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	97,044.3	0.0	
Optimum ST/SP	0.0	3,729.7	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	61.2	
Sub Total	0.0	100,773.9	61.2	
Economizer	0.0	1,911.2	0.0	
Ventilation/Recirculation	0.0	435.7	68.4	
DDC Control	0.0	18,640.1	20.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	121,760.9	150.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU2

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	7800
CFM - CLG	7800
% OA	17.79%
% Area	2.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU2

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	34,732.3	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	29.5	
Sub Total	0.0	36,039.3	29.5	
Economizer	0.0	770.4	0.0	
Ventilation/Recirculation	0.0	183.8	28.9	
DDC Control	0.0	7,513.8	10.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	44,507.4	68.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU3

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	4000
% OA	12.00%
% Area	0.96%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAV	1,680	
Heating HRSAV	2,688	
C/H HRSAV	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU3

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,489.5	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	10.1	
Sub Total	0.0	18,176.6	10.1	
Economizer	0.0	395.1	0.0	
Ventilation/Recirculation	0.0	63.6	0.0	
DDC Control	0.0	3,853.3	3.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	22,488.5	13.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU4

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	7480
CFM - CLG	7480
% OA	6.09%
% Area	1.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAV	1,680	
Heating HRSAV	2,688	
C/H HRSAV	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU4

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	31,855.2	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	10.5	
Sub Total	0.0	33,162.1	10.5	
Economizer	0.0	738.8	0.0	
Ventilation/Recirculation	0.0	60.3	9.5	
DDC Control	0.0	7,205.6	3.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	41,166.8	23.6	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU5

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	0
CFM - CLG	8500
% OA	9.69%
% Area	1.63%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type: 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU5

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	47,740.9	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	17.2	
Sub Total	0.0	49,681.0	17.2	
Economizer	0.0	839.5	0.0	
Ventilation/Recirculation	0.0	109.0	0.0	
DDC Control	0.0	8,188.2	5.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	58,817.7	23.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU6

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	1670
CFM - CLG	1670
% OA	11.98%
% Area	0.24%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU6

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	10,538.3	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	2.5	
Sub Total	0.0	10,964.1	2.5	
Economizer	0.0	164.9	0.0	
Ventilation/Recirculation	0.0	26.5	4.2	
DDC Control	0.0	1,608.7	0.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,764.3	7.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU7

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	900
CFM - CLG	1000
% OA	11.11%
% Area	0.12%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU7

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,041.8	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	1.3	
Sub Total	0.0	7,329.3	1.3	
Economizer	0.0	98.8	0.0	
Ventilation/Recirculation	0.0	14.7	2.1	
DDC Control	0.0	963.3	0.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,406.1	3.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU8

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	4600
CFM - CLG	4600
% OA	11.80%
% Area	1.47%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAV	1,680	
Heating HRSAV	2,688	
C/H HRSAV	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU8

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,254.1	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.5	
Sub Total	0.0	26,266.2	15.5	
Economizer	0.0	454.3	0.0	
Ventilation/Recirculation	0.0	71.9	11.3	
DDC Control	0.0	4,431.2	5.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	31,223.7	32.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU9

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	3495
CFM - CLG	3495
% OA	13.84%
% Area	1.47%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730
System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU9

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	17,501.4	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.5	
Sub Total	0.0	18,188.5	15.5	
Economizer	0.0	345.2	0.0	
Ventilation/Recirculation	0.0	64.1	10.1	
DDC Control	0.0	3,366.8	5.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	21,964.6	30.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 3
System Name: SINGLE ZONE AHU WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	1800
CFM - CLG	1800
% OA	10.00%
% Area	0.44%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730

System Type 3

System Name: SINGLE ZONE AHU WITHOUT RETURN FAN

System Number: AHU10

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,254.3	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	4.7	
Sub Total	0.0	7,541.9	4.7	
Economizer	0.0	177.8	0.0	
Ventilation/Recirculation	0.0	23.8	3.7	
DDC Control	0.0	1,734.0	1.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	9,477.4	10.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 12
System Name: BASEBOARD RADIATION
System Number: HE1

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	84.00%
TON CAPC.	0
MBTU CAPC.	2.101
kW/Ton	0
MOSON	8
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95
PAGE 2 OF 2

Bldg Number: 10730
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	18,686.9	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	886.0	
Sub Total	0.0	19,993.9	886.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	301.1	
HW OA Reset	0.0	0.0	15.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	19,993.9	1,202.7	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type: 11
System Name: CONDENSING UNIT
System Number: CH1

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	95
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAB	1,680	
Heating HRSAB	2,688	
C/H HRSAB	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 29-Mar-95
PAGE 2 OF 2

Bldg Number: 10730
System Type 11
System Name: CONDENSING UNIT
System Number: CH1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	909.2	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	909.2	0.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10730

Building Sq.Ft.: 76,848

System Type 11
System Name: CONDENSING UNIT
System Number: CH2

EMC NO.: 1406-006

DATE: 29-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1000	1000	1000	1000	1000	1000	1000
Stop Time	2000	2000	2000	2000	2000	2000	2000

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	95
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,680	3,360
Heating HRSON	2,688	5,376
C/H HRSON	4,380	8,760
Cooling HRSAV	1,680	
Heating HRSAV	2,688	
C/H HRSAV	4,380	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

29-Mar-95

PAGE 2 OF 2

Bldg Number: 10730
System Type: 11
System Name: CONDENSING UNIT
System Number: CH2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	909.2	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	909.2	0.0	3

ENERGY CALCULATIONS

BUILDING 10732

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10732

Building Sq.Ft.: 4,000

System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU1

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

*PROPANE IN-DUCT FURNACE

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer: 20

Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	1200	1200	1200	900	900	900	1200
Stop Time	1200	2000	2000	2100	2100	1700	1700

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	4000
CFM - CLG	4000
% OA	12.00%
% Area	100.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 10732
System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	13,981.3	0.0	
Optimum ST/SP	0.0	425.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	54.9	
Sub Total	0.0	14,407.2	54.9	
Economizer	0.0	305.7	0.0	
Ventilation/Recirculation	0.0	63.6	8.6	
DDC Control	0.0	2,981.7	18.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	17,758.1	82.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10732

Building Sq.Ft.: 4,000

System Type 11

System Name: CONDENSING UNIT

System Number: ACCU-1

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

*PROPANE IN-DUCT FURNACE

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1200	1200	1200	900	900	900	1200
Stop Time	1200	2000	2000	2100	2100	1700	1700

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	13.36
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAV	2,060	
Heating HRSAV	3,296	
C/H HRSAV	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	0.00
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 10732
System Type: 11
System Name: CONDENSING UNIT
System Number: ACCU-1

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	945.2	0.0	
Optimum ST/SP	0.0	86.3	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.9	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.9	1,031.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.9	1,031.5	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10732

Building Sq.Ft.: 4,000

System Type 11

System Name: CONDENSING UNIT

System Number: ACCU-2

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

*PROPANE IN-DUCT FURNACE

Typical Building Information

Category	Construction	Use	Occ.	Day
21	BRICK	CLO SALES/RETAIL/COM	1000-2000	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	1200	1200	1200	900	900	900	1200
Stop Time	1200	2000	2000	2100	2100	1700	1700

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.5
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	13.36
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,300	3,360
Heating HRSON	2,080	5,376
C/H HRSON	3,389	8,760
Cooling HRSAB	2,060	
Heating HRSAB	3,296	
C/H HRSAB	5,371	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.84E-03	1.84E-03
COAUHC	7.04E-04	7.04E-04
HOAOH	214.18	214.18
HOAOHC	131.44	131.44
COAOC	5.98E-03	5.98E-03
COAOHC	2.29E-03	2.29E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	5.88E-05	5.88E-05
ECHC	2.26E-05	2.26E-05
NSUCC	1.54E-04	1.54E-04
NSUCHC	9.45E-05	9.45E-05
DDCCHC	8.44E-05	8.44E-05
DDCCC	2.20E-04	2.20E-04
DSC	4.66E+03	4.66E+03
NSC	1.37E+04	1.37E+04
FV	93	93
CHWR	9.57	0.00
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

10-Apr-95

PAGE 2 OF 2

Bldg Number: 10732

System Type 11

System Name: CONDENSING UNIT

System Number: ACCU-2

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	945.2	0.0	
Optimum ST/SP	0.0	86.3	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.9	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.9	1,031.5	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.9	1,031.5	0.0	3

ENERGY CALCULATIONS

BUILDING 10745

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10745

Building Sq.Ft.: 23,500

System Type 12
System Name: BASEBOARD RADIATION
System Number: HX-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	600	1900	1900	1900	1900	1900	600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	26.00%
TON CAPC.	0
MBTU CAPC.	2.155
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,720	3,360
Heating HRSON	2,752	5,376
C/H HRSON	4,484	8,760
Cooling HRSAB	1,640	
Heating HRSAB	2,624	
C/H HRSAB	4,276	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10745
System Type 12
System Name: BASEBOARD RADIATION
System Number: HX-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,013.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	598.1	
Sub Total	0.0	4,300.8	598.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	155.7	
HW OA Reset	0.0	0.0	15.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,300.8	769.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10745

Building Sq.Ft.: 23,500

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	3445
CFM - CLG	0
% OA	25.30%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10745

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,815.4	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	552.1	
Sub Total	0.0	8,103.0	552.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	143.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,103.0	695.8	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10745

Building Sq.Ft.: 23,500

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2400
CFM - CLG	0
% OA	100.00%
% Area	16.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10745

System Type: 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	386.5	
Sub Total	0.0	6,850.0	386.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	100.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	487.1	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10745

Building Sq.Ft.: 23,500

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2359
CFM - CLG	0
% OA	25.30%
% Area	16.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10745

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	379.6	
Sub Total	0.0	6,850.0	379.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	98.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	478.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10745

Building Sq.Ft.: 23,500

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2359
CFM - CLG	0
% OA	25.30%
% Area	16.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10745

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	379.6	
Sub Total	0.0	6,850.0	379.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	98.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	478.4	3

ENERGY CALCULATIONS

BUILDING 10785

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 3,024

System Type 2

System Name: H&V UNIT

System Number: AHU1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
24	BRICK	CHAPEL ZONE	0800-1400	SUN

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	800	0	0	0	0	0	0
Stop Time	1400	0	0	0	0	0	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	17.5
Load Factor	0.8
CFM - HTG	4100
CFM - CLG	0
% OA	48.78%
% Area	58.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	160	3,360
Heating HRSON	256	5,376
C/H HRSON	417	8,760
Cooling HRSAV	3,200	
Heating HRSAV	5,120	
C/H HRSAV	8,343	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	372.76	372.76
HOAOHC	185.87	185.87
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	7.01E+03	7.01E+03
NSC	2.51E+05	2.51E+05
FV	147	147
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785
System Type 2
System Name: H&V UNIT
System Number: AHU1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	100,445.3	0.0	
Optimum ST/SP	0.0	2,263.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	441.0	
Sub Total	0.0	102,708.8	441.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	9.4	
DDC Control	0.0	0.0	12.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	102,708.8	462.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 7,048

System Type 2

System Name: H&V UNIT

System Number: AHU2

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
25	BRICK	CHAPEL OFFICE ZONE	0600-1700	SUN-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	830	0	900	0	900	0	0
Stop Time	1300	0	1200	0	1200	0	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	11.65
Load Factor	0.8
CFM - HTG	2900
CFM - CLG	0
% OA	31.03%
% Area	73.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	334	3,360
Heating HRSON	534	5,376
C/H HRSON	871	8,760
Cooling HRSAB	3,026	
Heating HRSAB	4,842	
C/H HRSAB	7,889	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	347.79	347.79
HOAOHC	173.42	173.42
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	1.26E+04	1.26E+04
NSC	3.30E+04	3.30E+04
FV	52	52
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785

System Type 2

System Name: H&V UNIT

System Number: AHU2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	63,895.2	0.0	
Optimum ST/SP	0.0	1,522.6	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	169.6	
Sub Total	0.0	65,417.8	169.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	4.5	
DDC Control	0.0	0.0	64.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	65,417.8	238.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU3

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6.7
Load Factor	0.8
CFM - HTG	3500
CFM - CLG	0
% OA	19.29%
% Area	6.83%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785
System Type 2
System Name: H&V UNIT
System Number: AHU3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,026.6	0.0	
Optimum ST/SP	0.0	920.7	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	15.8	
Sub Total	0.0	25,947.3	15.8	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	27.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	25,947.3	43.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU4

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	14.15
Load Factor	0.8
CFM - HTG	3500
CFM - CLG	0
% OA	12.00%
% Area	13.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785
System Type 2
System Name: H&V UNIT
System Number: AHU4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	50,267.3	0.0	
Optimum ST/SP	0.0	1,849.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.9	
Sub Total	0.0	52,116.7	31.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	55.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	52,116.7	87.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU5

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	2800
CFM - CLG	0
% OA	25.00%
% Area	11.10%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785
System Type 2
System Name: H&V UNIT
System Number: AHU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	35,524.6	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	25.6	
Sub Total	0.0	36,831.6	25.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	44.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	36,831.6	70.3	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU6

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	17.475
Load Factor	0.8
CFM - HTG	4850
CFM - CLG	0
% OA	20.62%
% Area	19.22%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785

System Type 2

System Name: H&V UNIT

System Number: AHU6

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	61,434.9	0.0	
Optimum ST/SP	0.0	2,260.2	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	44.4	
Sub Total	0.0	63,695.1	44.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	77.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	63,695.1	121.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU7

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	6.3
Load Factor	0.8
CFM - HTG	1975
CFM - CLG	0
% OA	30.38%
% Area	7.81%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785
System Type 2
System Name: H&V UNIT
System Number: AHU7

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	23,532.5	0.0	
Optimum ST/SP	0.0	865.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	18.0	
Sub Total	0.0	24,398.2	18.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	31.4	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	24,398.2	49.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU8

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	10
Load Factor	0.8
CFM - HTG	2850
CFM - CLG	0
% OA	21.05%
% Area	11.26%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785

System Type 2

System Name: H&V UNIT

System Number: AHU8

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	35,524.6	0.0	
Optimum ST/SP	0.0	1,307.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	26.0	
Sub Total	0.0	36,831.6	26.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	45.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	36,831.6	71.3	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 2

System Name: H&V UNIT

System Number: AHU9

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	11.65
Load Factor	0.8
CFM - HTG	3475
CFM - CLG	0
% OA	25.90%
% Area	13.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	85.80% 85.80%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSVA	1,960	
Heating HRSVA	3,136	
C/H HRSVA	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785

System Type 2

System Name: H&V UNIT

System Number: AHU9

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	41,386.2	0.0	
Optimum ST/SP	0.0	1,522.6	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	31.9	
Sub Total	0.0	42,908.8	31.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	55.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	42,908.8	87.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: AHU10

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3.75
Load Factor	0.8
CFM - HTG	1800
CFM - CLG	0
% OA	100.00%
% Area	7.10%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSVA	1,960	
Heating HRSVA	3,136	
C/H HRSVA	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95

PAGE 2 OF 2

Bldg Number: 10785

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: AHU10

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	14,468.4	0.0	
Optimum ST/SP	0.0	532.3	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	16.4	
Sub Total	0.0	15,000.7	16.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	28.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	15,000.7	45.0	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10785

Building Sq.Ft.: 40,519

System Type 12

System Name: BASEBOARD RADIATION

System Number: HE1

EMC NO.: 1406-006

DATE: 28-Mar-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
23	BRICK	CHAPEL/REL ED/CHILD C	0600-1800	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	830	600	600	600	600	600	0
Stop Time	1300	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	25.80%
TON CAPC.	0
MBTU CAPC.	2.001
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,534	3,360
Heating HRSON	2,454	5,376
C/H HRSON	3,999	8,760
Cooling HRSAV	1,826	
Heating HRSAV	2,922	
C/H HRSAV	4,761	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	231.05	231.05
HOAOHC	115.21	115.21
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	9.94E+03	9.94E+03
NSC	5.70E+03	5.70E+03
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 28-Mar-95
PAGE 2 OF 2

Bldg Number: 10785
System Type 12
System Name: BASEBOARD RADIATION
System Number: HE1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,010.8	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	59.5	
Sub Total	0.0	2,140.2	59.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	103.9	
HW OA Reset	0.0	0.0	14.8	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,140.2	178.2	3

ENERGY CALCULATIONS

BUILDING 10790

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10790

Building Sq.Ft.: 21,820

System Type 12

System Name: BASEBOARD RADIATION

System Number: HX-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	600	1900	1900	1900	1900	1900	600

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	26.00%
TON CAPC.	0
MBTU CAPC.	2.155
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,720	3,360
Heating HRSON	2,752	5,376
C/H HRSON	4,484	8,760
Cooling HRSAB	1,640	
Heating HRSAB	2,624	
C/H HRSAB	4,276	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DCCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10790
System Type 12
System Name: BASEBOARD RADIATION
System Number: HX-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	4,013.2	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	555.4	
Sub Total	0.0	4,300.8	555.4	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	144.5	
HW OA Reset	0.0	0.0	15.9	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	4,300.8	715.9	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10790

Building Sq.Ft.: 21,820

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	3445
CFM - CLG	0
% OA	25.30%
% Area	24.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 10790
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	7,815.4	0.0	
Optimum ST/SP	0.0	287.5	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	552.1	
Sub Total	0.0	8,103.0	552.1	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	143.7	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	8,103.0	695.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10790

Building Sq.Ft.: 21,820

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-2

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2400
CFM - CLG	0
% OA	100.00%
% Area	16.80%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 10790

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	386.5	
Sub Total	0.0	6,850.0	386.5	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	100.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	487.1	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10790

Building Sq.Ft.: 21,820

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2359
CFM - CLG	0
% OA	25.30%
% Area	16.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAV	1,960	
Heating HRSAV	3,136	
C/H HRSAV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10790

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-3

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	379.6	
Sub Total	0.0	6,850.0	379.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	98.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	478.4	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 10790

Building Sq.Ft.: 21,820

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-4

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
22	BRICK	CHILD SUPPORT CENTER	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1.5
Load Factor	0.8
CFM - HTG	2359
CFM - CLG	0
% OA	25.30%
% Area	16.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAV	1,960	
Heating HRSAV	3,136	
C/H HRSAV	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	91.77	91.77
HOAOHC	56.32	56.32
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.55E+04	2.55E+04
NSC	9.79E+04	9.79E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

05-Apr-95

PAGE 2 OF 2

Bldg Number: 10790

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-4

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	6,607.0	0.0	
Optimum ST/SP	0.0	243.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	379.6	
Sub Total	0.0	6,850.0	379.6	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	98.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	6,850.0	478.4	3

ENERGY CALCULATIONS

BUILDING 11050

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HX-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	2.16
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	0	194
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 11050

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	16.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	16.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B-1

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	1
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	69.20% 69.20%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 11050
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	6.7	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	6.7	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type: 12
System Name: BASEBOARD RADIATION
System Number: HX-1A

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0.75
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	18.70%
TON CAPC.	0
MBTU CAPC.	0.4393
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	65.00% 65.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	194
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 11050
System Type 12
System Name: BASEBOARD RADIATION
System Number: HX-1A

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	2,158.3	0.0	
Optimum ST/SP	0.0	129.4	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	619.0	
Sub Total	0.0	2,287.7	619.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	63.6	
HW OA Reset	0.0	0.0	3.3	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	2,287.7	685.9	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 7

System Name: VAV AHU

System Number: AHU-1

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	15
Load Factor	0.8
CFM - HTG	7645
CFM - CLG	10130
% OA	46.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	86.70% 86.70%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	194
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 11050
System Type 7
System Name: VAV AHU
System Number: AHU-1

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	66,161.8	0.0	
Optimum ST/SP	0.0	1,940.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	297.9	
Sub Total	0.0	68,101.9	297.9	
	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	494.0	109.4	
DDC Control	0.0	959.8	30.6	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	0.0	69,555.7	438.0	6

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 9,278

System Type 7

System Name: VAV AHU

System Number: AHU-2

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
27	BRICK	CLINIC W/O BEDS/SUPPL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	2470
CFM - CLG	3190
% OA	26.00%
% Area	31.50%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	2.24E-04	2.24E-04
DDCCC	6.71E-04	6.71E-04
DSC	6.29E+04	6.29E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 11050
System Type 7
System Name: VAV AHU
System Number: AHU-2

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	18,743.3	183.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	0.0	18,743.3	183.8	6

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 9,278

System Type: 4
System Name: SINGLE ZONE AHU
System Number: AHU-3

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
27	BRICK	CLINIC W/O BEDS/SUPPL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	2100
CFM - CLG	2100
% OA	100.00%
% Area	30.30%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	2.24E-04	2.24E-04
DDCCC	6.71E-04	6.71E-04
DSC	6.29E+04	6.29E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95
PAGE 2 OF 2

Bldg Number: 11050
System Type 4
System Name: SINGLE ZONE AHU
System Number: AHU-3

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	12,338.9	176.8	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	12,338.9	176.8	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 9,278

System Type 7

System Name: VAV AHU

System Number: AHU-4

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
27	BRICK	CLINIC W/O BEDS/SUPPL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	3475
CFM - CLG	4005
% OA	35.00%
% Area	23.18%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DCCCHC	2.24E-04	2.24E-04
DDCCC	6.71E-04	6.71E-04
DSC	6.29E+04	6.29E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95
PAGE 2 OF 2

Bldg Number: 11050
System Type 7
System Name: VAV AHU
System Number: AHU-4

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	23,532.0	135.2	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	0.0	23,532.0	135.2	6

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 7

System Name: VAV AHU

System Number: AHU-5

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	3720
CFM - CLG	9915
% OA	25.00%
% Area	4.39%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1

LOOK-UP VALUE

EFFHP	81.60%	81.60%
-------	--------	--------

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	194
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 11050
System Type 7
System Name: VAV AHU
System Number: AHU-5

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	25,819.5	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	7.3	0.0	0.0	
Night Setback	0.0	0.0	145.3	
Sub Total	7.3	26,506.6	145.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	262.8	28.9	
DDC Control	0.0	939.4	14.9	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	7.3	27,708.8	189.2	6

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 7

System Name: VAV AHU

System Number: AHU-6

EMC NO.: 1406-006

DATE: 10-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11035
CFM - CLG	13685
% OA	25.00%
% Area	13.03%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAH	0.00	0.00
HOAH	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAH	130.00	130.00
HOAH	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 10-Apr-95

PAGE 2 OF 2

Bldg Number: 11050
System Type 7
System Name: VAV AHU
System Number: AHU-6

HEATING AND COOLING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	28,535.4	0.0	
Optimum ST/SP	0.0	687.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	7.3	0.0	0.0	
Night Setback	0.0	0.0	431.3	
Sub Total	7.3	29,222.6	431.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	362.7	0.0	
DDC Control	0.0	1,296.6	44.3	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				6
TOTAL	7.3	30,881.9	475.7	6

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-1

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	5000
CFM - CLG	0
% OA	25.00%
% Area	5.90%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95

PAGE 2 OF 2

Bldg Number: 11050

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: HV-1

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	15,433.0	0.0	
Optimum ST/SP	0.0	567.8	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	195.3	
Sub Total	0.0	16,000.8	195.3	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	20.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	16,000.8	215.4	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-2

EMC NO.: 1406-006

DATE: 04-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer: 20
Enter Weeks of Winter: 32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	700	700	700	700	700	0
Stop Time	0	1900	1900	1900	1900	1900	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	7.5
Load Factor	0.8
CFM - HTG	9000
CFM - CLG	0
% OA	25.00%
% Area	10.60%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	83.10% 83.10%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	3,360
Heating HRSON	2,240	5,376
C/H HRSON	3,650	8,760
Cooling HRSAB	1,960	
Heating HRSAB	3,136	
C/H HRSAB	5,110	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	194
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 04-Apr-95
PAGE 2 OF 2

Bldg Number: 11050
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: HV-2

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	27,509.1	0.0	
Optimum ST/SP	0.0	1,012.1	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	350.9	
Sub Total	0.0	28,521.2	350.9	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	70.0	
DDC Control	0.0	0.0	36.1	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	28,521.2	457.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type: 8
System Name: CHILLER AND PUMPS
System Number: CHR-1A,B,C

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	54.4
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	78.00% 78.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 11050

System Type 8

System Name: CHILLER AND PUMPS

System Number: CHR-1A,B,C

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	3.1	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	3.1	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	520.6	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	3.1	520.6	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 9,278

System Type 11

System Name: CONDENSING UNIT

System Number: ACCU1A-3B

EMC NO.: 1406-006

DATE: 05-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
27	BRICK	CLINIC W/O BEDS/SUPPL	0000-2400	SUN-SAT

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	4
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	42.8
MBTU CAPC.	0
kW/Ton	0
MOSON	5
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	0.00	0.00
HOAOHC	0.00	0.00
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	2.24E-04	2.24E-04
DDCCC	6.71E-04	6.71E-04
DSC	6.29E+04	6.29E+04
NSC	0.00E+00	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	0.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 05-Apr-95

PAGE 2 OF 2

Bldg Number: 11050

System Type 11

System Name: CONDENSING UNIT

System Number: ACCU1A-3B

COOLING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	6.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	6.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	409.6	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	6.0	409.6	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11050

Building Sq.Ft.: 67,570

System Type 13

System Name: STEAM HUMIDIFICATION

System Number: B-1

EMC NO.: 1406-006

DATE: 19-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
26	BRICK	CLINIC W/O BEDS/SUPPL	0700-1900	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	700	700	700	700	700	700	700
Stop Time	1700	1700	1700	1700	1700	1700	170

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.9
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,374	3,360
Heating HRSON	2,198	5,376
C/H HRSON	3,582	8,760
Cooling HRSAV	1,986	
Heating HRSAV	3,178	
C/H HRSAV	5,178	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	1.37E-03	1.37E-03
COAUHC	5.64E-04	5.64E-04
HOAOH	130.00	130.00
HOAOHC	64.82	64.82
COAOC	6.15E-03	6.15E-03
COAOHC	2.06E-03	2.06E-03
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	2.13E-04	2.13E-04
NSUCHC	1.44E-04	1.44E-04
DDCCHC	8.68E-06	8.68E-06
DDCCC	2.60E-05	2.60E-05
DSC	5.04E+03	5.04E+03
NSC	4.90E+04	4.90E+04
FV	194	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 19-Apr-95
PAGE 2 OF 2

Bldg Number: 11050
System Type 13
System Name: STEAM HUMIDIFICATION
System Number: B-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	6.7	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				0
TOTAL	0.0	0.0	6.7	3

ENERGY CALCULATIONS

BUILDING 11142

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11142

Building Sq.Ft.: 1,465

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

EMC NO.: 1406-006

DATE: 17-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.455
kW/Ton	0
MOSON	0
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	5.85E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 17-Apr-95
PAGE 2 OF 2

Bldg Number: 11142
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	3.4	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.4	3

ENERGY CALCULATIONS

BUILDING 11144

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 11144

Building Sq.Ft.: 4,200

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

EMC NO.: 1406-006

DATE: 17-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0.269
kW/Ton	0
MOSON	0
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAN	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	5.85E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 17-Apr-95

PAGE 2 OF 2

Bldg Number: 11144

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	2.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	2.0	3

ENERGY CALCULATIONS

BUILDING 21517

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510/21516/21517

Building Sq.Ft.: 19,247

System Type 9
System Name: CONVERTER AND PUMPS
System Number: HX-1

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

Present Operations	S	M	T	W	TH	F	S
Start Time	0	0	0	0	0	0	0
Stop Time	2400	2400	2400	2400	2400	2400	2400

INPUTS	INPUT
Motor HP	2
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	12
EFF	1

LOOK-UP VALUE

EFFHP	78.00%	78.00%
-------	--------	--------

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	3,360	3,360
Heating HRSON	5,376	5,376
C/H HRSON	8,760	8,760
Cooling HRSVA	0	
Heating HRSVA	0	
C/H HRSVA	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	5.85E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510/21516/21517

System Type 9

System Name: CONVERTER AND PUMPS

System Number: HX-1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	0.0	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 10

System Name: HOT WATER BOILER AND PUMPS

System Number: B1

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	6.695
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	5.85E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95
PAGE 2 OF 2

Bldg Number: 21510
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B1

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	49.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	49.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B2

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	0
Load Factor	0.8
CFM - HTG	0
CFM - CLG	0
% OA	0.00%
% Area	0.00%
TON CAPC.	0
MBTU CAPC.	6.695
kW/Ton	0
MOSON	12
EFF	1
LOOK-UP VALUE	
EFFHP	0.00% 0.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	5.85E+04
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	188.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95
PAGE 2 OF 2

Bldg Number: 21510
System Type 10
System Name: HOT WATER BOILER AND PUMPS
System Number: B2

HEATING ONLY SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	0.0	
HW OA Reset	0.0	0.0	49.5	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	49.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU01

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU01

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU02

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	5625
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU02

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU03

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95
PAGE 2 OF 2

Bldg Number: 21510
System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU03

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU04

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU04

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU5

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	5625
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU5

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU06

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU06

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU07

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	5625
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU07

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type: 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU08

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	3
Load Factor	0.8
CFM - HTG	5625
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	79.00% 79.00%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRSAB	0	
Heating HRSAB	0	
C/H HRSAB	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU08

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

EMC ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU09

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRSAV	0	
Heating HRSAV	0	
C/H HRSAV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date:

07-Apr-95

PAGE 2 OF 2

Bldg Number: 21510

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU09

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

BLDG: 21510

Building Sq.Ft.: 19,247

System Type 1

System Name: H&V UNIT WITHOUT RETURN FAN

System Number: MAU10

EMC NO.: 1406-006

DATE: 07-Apr-95

PREPARED BY: CSW/BMG

CHECKED BY: KC/WLC

PAGE 1 OF 2

Typical Building Information

Category	Construction	Use	Occ.	Day
2	BRICK	MOTOR REPAIR SHOP	0600-1730	MON-FRI

Enter Weeks of Summer:

20

Enter Weeks of Winter:

32

Required Operation	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

Present Operations	S	M	T	W	TH	F	S
Start Time	0	600	600	600	600	600	0
Stop Time	0	1800	1800	1800	1800	1800	0

INPUTS	INPUT
Motor HP	5
Load Factor	0.8
CFM - HTG	11250
CFM - CLG	0
% OA	100.00%
% Area	9.00%
TON CAPC.	0
MBTU CAPC.	0
kW/Ton	0
MOSON	7
EFF	1
LOOK-UP VALUE	
EFFHP	81.60% 81.60%

HOURS CALCULATIONS	REQUIRED HR/YR	PRESENT HR/YR
Cooling HRSON	1,400	1,200
Heating HRSON	2,240	1,920
C/H HRSON	3,650	3,129
Cooling HRS AV	0	
Heating HRS AV	0	
C/H HRS AV	0	

CONSTANT	LOOK-UP	INPUT
HOAUH	0.00	0.00
HOAUHC	0.00	0.00
COAUC	0.00E+00	0.00E+00
COAUHC	0.00E+00	0.00E+00
HOAOH	198.24	198.24
HOAOHC	121.66	121.66
COAOC	0.00E+00	0.00E+00
COAOHC	0.00E+00	0.00E+00
DC DUTY	0.00	0.00
DC DEMAND	0.17	0.17
ECC	0.00E+00	0.00E+00
ECHC	0.00E+00	0.00E+00
NSUCC	0.00E+00	0.00E+00
NSUCHC	0.00E+00	0.00E+00
DDCCHC	0.00E+00	0.00E+00
DDCCC	0.00E+00	0.00E+00
DSC	2.04E+03	2.04E+03
NSC	5.85E+04	0.00E+00
FV	0	0
CHWR	9.57	9.57
OAR	7.40	7.40
OPT	188.00	0.00

E M C ENGINEERS, INC.

PROJECT: UMCS FEASIBILITY STUDY

CLIENT CONTRACT NO.: DACA01-94-D-0033 D.O. 6

CLIENT PROJECT ENGINEER: STEVE ROWLEY

LOCATION: FT. DRUM

Date: 07-Apr-95
PAGE 2 OF 2

Bldg Number: 21510
System Type 1
System Name: H&V UNIT WITHOUT RETURN FAN
System Number: MAU10

HEATING AND VENTILATING SYSTEMS	kW/yr	kWh/yr	MBtu/yr	MH/yr
Schedule ST/SP	0.0	0.0	0.0	
Optimum ST/SP	0.0	0.0	0.0	
Duty Cycle	0.0	0.0	0.0	
Demand Limit	0.0	0.0	0.0	
Night Setback	0.0	0.0	0.0	
Sub Total	0.0	0.0	0.0	
Economizer	0.0	0.0	0.0	
Ventilation/Recirculation	0.0	0.0	0.0	
DDC Control	0.0	0.0	3.5	
HW OA Reset	0.0	0.0	0.0	
Chilled Water Reset	0.0	0.0	0.0	
Condenser Water Reset	0.0	0.0	0.0	
Chiller Demand Limit	0.0	0.0	0.0	
Remote Monitoring, Maintenance, Run Time, and Safety Alarms				3
TOTAL	0.0	0.0	3.5	3